



Struisbult PV2 (Pty) Ltd

Top Floor, Golf Park 4,
Raapenberg Road,
Mowbray
Western Cape
7700

14 January 2022

Attention: Warren Morse

Enquiries: L Stroh

Tel. 011 545 1232

strohl@caa.co.za

Ref. CA8/2/Alkantpan

CAA_2021_5_242

Conditional Approved: Proposed Struisbult PV2, PV Solar Photovoltaic Power Energy Facility situated near Platsambok in the Northern Cape Province.

After evaluating the site position and reviewing the information received 25 May 2021, the SACAA has **no objection** to the proposed Energy Facility subject to a maximum height of 21m above ground level. SACAA reserves the right to request panels realign (optimum position) or removal, if any Safety concerns are raised towards Glint and Glare.

The proposed new Overhead Electric Power/Transmission Line is restricted to a maximum of 25m above ground level.

The above statement is conditional to the developer, providing the SACAA with the "as built" parameters of the facility, which includes the height of the pylon structures conveying power generated by the facility.

This conditional approval is valid for 5 years from the date of this letter.

Note that this SACAA letter of no objection does not substitute or replace other approvals which may be required by the applicant.

Yours truly,

Lizell Stroh

Obstacle Inspector

PANS-OPS Section

Air Navigation Services Department

Tel: +27 11 545 1232 | Mobile: +27 083 461 6660

Email: Strohl@caa.co.za | www.caa.co.za