

SAH CONSULTING ENGINEERS

PO BOX 1839

VERULAM

4340

TEL.: 072 378 1364

09 March 2023


RE: REPORT ON EXISTING ROOF STRUCTURE.

Client : D.G.S.Holdings & Investments (Pty). Ltd.

**Lot No.: Portion 1 of 517 Brickfield - 11 Palm Grove Overport.
Durban.**

This is to confirm that upon inspection of the roof structure at the above mentioned premises we found the structure to be badly infested by borers which made the structure unsafe to live under. We recommended that the entire roof and all woodwork be removed and replaced by new trusses duly treated as per National Building Regulations.

Yours Faithfully



.....
Shabbir Habib Pr. Tech Eng.

ECSA Registration No.201070024