



environmental affairs

Department:
Environmental Affairs
REPUBLIC OF SOUTH AFRICA

DETAILS OF THE SPECIALIST, DECLARATION OF INTEREST AND UNDERTAKING UNDER OATH

	(For official use only)
File Reference Number:	
NEAS Reference Number:	DEA/EIA/
Date Received:	

Application for authorisation in terms of the National Environmental Management Act, Act No. 107 of 1998, as amended and the Environmental Impact Assessment (EIA) Regulations, 2014, as amended (the Regulations)

PROJECT TITLE

Ndau 1 Solar Energy Facility

Kindly note the following:

1. This form must always be used for applications that must be subjected to Basic Assessment or Scoping & Environmental Impact Reporting where this Department is the Competent Authority.
2. This form is current as of 01 September 2018. It is the responsibility of the Applicant / Environmental Assessment Practitioner (EAP) to ascertain whether subsequent versions of the form have been published or produced by the Competent Authority. The latest available Departmental templates are available at <https://www.environment.gov.za/documents/forms>.
3. A copy of this form containing original signatures must be appended to all Draft and Final Reports submitted to the department for consideration.
4. All documentation delivered to the physical address contained in this form must be delivered during the official Departmental Officer Hours which is visible on the Departmental gate.
5. All EIA related documents (includes application forms, reports or any EIA related submissions) that are faxed; emailed; delivered to Security or placed in the Departmental Tender Box will not be accepted, only hardcopy submissions are accepted.

Departmental Details

Postal address:

Department of Environmental Affairs
Attention: Chief Director: Integrated Environmental Authorisations
Private Bag X447
Pretoria
0001

Physical address:

Department of Environmental Affairs
Attention: Chief Director: Integrated Environmental Authorisations
Environment House
473 Steve Biko Road
Arcadia

Queries must be directed to the Directorate: Coordination, Strategic Planning and Support at:
Email: EIAAdmin@environment.gov.za

1. SPECIALIST INFORMATION

Specialist Company Name:	Environmental Planning and Design		
B-BBEE	Contribution level (indicate 1 to 8 or non-compliant)	4	Percentage Procurement recognition
Specialist name:	Jonathan Marshall		
Specialist Qualifications:	Dip.LA.		
Professional affiliation/registration:	Chartered Member of the Landscape Institute (UK). Registered Professional Landscape Architect (South Africa).		
Physical address:	7 Carlton Avenue, Westville, 3629		
Postal address:	PO Box 50910, Musgrave Road, Durban		
Postal code:	3629	Cell:	083 703 2995
Telephone:		Fax:	
E-mail:	jon@enviroconsult.co.za		

2. DECLARATION BY THE SPECIALIST

I, Jonathan Marshall, declare that –

- I act as the independent specialist in this application;
- I will perform the work relating to the application in an objective manner, even if this results in views and findings that are not favourable to the applicant;
- I declare that there are no circumstances that may compromise my objectivity in performing such work;
- I have expertise in conducting the specialist report relevant to this application, including knowledge of the Act, Regulations and any guidelines that have relevance to the proposed activity;
- I will comply with the Act, Regulations and all other applicable legislation;
- I have no, and will not engage in, conflicting interests in the undertaking of the activity;
- I undertake to disclose to the applicant and the competent authority all material information in my possession that reasonably has or may have the potential of influencing - any decision to be taken with respect to the application by the competent authority; and - the objectivity of any report, plan or document to be prepared by myself for submission to the competent authority;
- all the particulars furnished by me in this form are true and correct; and
- I realise that a false declaration is an offence in terms of regulation 48 and is punishable in terms of section 24F of the Act.

Signature of the Specialist

Environmental Planning and Design

Name of Company:

19th May 2023

Date

3. UNDERTAKING UNDER OATH/ AFFIRMATION

I, Jonathan Marshall, swear under oath / affirm that all the information submitted or to be submitted for the purposes of this application is true and correct.

J. Marshall

Signature of the Specialist

Environmental Planning and Design

Name of Company

19th May 2023

Date

71825533
SCA
J.P. Tunda

Signature of the Commissioner of Oaths

19/05/2023

Date



ABO NDAU SOLAR ENERGY FACILITY 1 (PTY) LTD

**PROPOSED ESTABLISHMENT OF NDAU SOLAR ENERGY FACILITY 1 AND
ASSOCIATED INFRASTRUCTURE ON PORTION 19 OF THE FARM RIETVLEY
NO 13 JQ NEAR POLOKWANE, LIMPOPO PROVINCE**

LANDSCAPE & VISUAL IMPACT BASELINE REPORT

MAY 2023

Prepared by:

Environmental Planning and Design
72 Carlton Avenue,
Westville,
Durban,
3629

Tel: 083 703 2995

Email: jon@enviroconsult.co.za

Prepared for:

Praxos 373
31 Saint Margaret Street
Hurlyvale
Edenvale,
1611

Tel: 011 453 8727

Fax: 086 414 3312

Email: Richard.Myburg@praxos373.co.za



ENVIRONMENTAL PLANNING AND DESIGN

PO BOX 2122, WESTVILLE, 3630, SOUTH AFRICA

TABLE OF CONTENTS

1	INTRODUCTION	4
1.1	GENERAL	4
1.2	PROJECT LOCATION	4
1.3	BACKGROUND OF SPECIALIST	4
1.4	THE NATURE OF VISUAL IMPACT	4
1.5	RELEVANT GUIDELINES	5
1.6	SCOPING OBJECTIVES	7
1.7	LIMITATIONS AND ASSUMPTIONS	7
2.	PROJECT DESCRIPTION	10
2.1	PROJECT COMPONENTS	10
2.2	OVERVIEW OF SOLAR PV TECHNOLOGY	11
2.3	THE LIKELY NATURE OF VIEWS OF THE PROPOSED PROJECT	13
2.3.1	SOLAR ARRAY	13
2.3.2	THE ELECTRICAL INFRASTRUCTURE COMPOUND	18
2.4	VISUAL LIMITS	19
3.	DESCRIPTION OF RECEIVING ENVIRONMENT AND RECEPTORS	21
3.1	LANDSCAPE CHARACTER	21
3.1.1	LANDFORM AND DRAINAGE	21
3.1.2	LANDCOVER	22
3.2	LANDSCAPE CHARACTER AREAS & VISUAL ABSORPTION CAPACITY	24
3.3	LANDSCAPE QUALITY AND IMPORTANCE	27
3.4	VISUAL RECEPTORS	28
3.4.1	DEFINITION	28
3.4.2	VISUAL RECEPTORS	28
3.5	LIKELY SENSITIVITY OF LCA'S AND RECEPTORS	28
4	SITE SENSITIVITY	31
4.1	NO GO DEVELOPMENT AREAS	31
4.2	SITE DEVELOPMENT SENSITIVITY	31
5	IDENTIFICATION AND INITIAL ASSESSMENT OF ISSUES	33
5.1	IMPACTS TO BE CONSIDERED	33
5.2	SIGNIFICANCE OF ISSUES	33
5.3	INITIAL ASSESSMENT OF ISSUES	33
5.3.1	LANDSCAPE CHANGE	33
5.3.2	MAIN ROADS	34
5.3.3	LOCAL ROADS	34
5.3.4	HOMESTEADS	35
5.3.5	PROTECTED AREAS	36
5.3.6	LIGHTING	36
6	RECOMMENDED ASSESSMENT METHODOLOGY	38
6.1	REQUIREMENTS IN ACCORDANCE WITH THE WESTERN CAPE GUIDELINES	38
6.2	DETAILED METHODOLOGY	39
6.2.1	IDENTIFICATION OF ISSUES RAISED IN SCOPING PHASE, AND SITE VISIT	39
6.2.2	DESCRIPTION OF THE RECEIVING ENVIRONMENT AND THE PROPOSED PROJECT	39
6.2.3	ESTABLISHMENT OF VIEW CATCHMENT AREA, VIEW CORRIDORS, VIEWPOINTS AND RECEPTORS	39
6.2.4	INDICATION OF POTENTIAL VISUAL IMPACTS USING ESTABLISHED CRITERIA	40
6.2.5	INCLUSION OF POTENTIAL LIGHTING IMPACTS AT NIGHT	40
6.2.6	DESCRIPTION OF ALTERNATIVES, MITIGATION MEASURES AND MONITORING PROGRAMME	40
	40	
	REFERENCES	41
<u>APPENDICES</u>		
I	SPECIALIST'S BRIEF CV	
II	WESTERN CAPE GUIDELINES	
II	FORMULA FOR DERIVING THE APPROXIMATE VISUAL HORIZON	

MAPS

- 1 SITE LOCATION
- 2 SITE LAYOUT
- 3 LANDFORM AND DRAINAGE
- 4 LANDCOVER
- 5 SITE SENSITIVITY

PHOTOGRAPHIC PLATES

- 1 EXISTING SOLAR ARRAYS AT UPINGTON AIRPORT AS SEEN FROM THE AIR
- 2 EXISTING ARRAY SEEN IN A FLAT LANDSCAPE FROM APPROXIMATELY 700M.
- 3 EXISTING ARRAY SEEN IN A FLAT LANDSCAPE FROM APPROXIMATELY 1500M
- 4 EXISTING ARRAY SEEN IN A FLAT LANDSCAPE FROM APPROXIMATELY 5000M
- 5 A SINGLE AXIS TRACKING SOLAR PV PROJECT IN THE NORTH WEST PROVINCE (BOKAMOSO SOLAR PV PLANT) PHOTOGRAPHED AT APPROXIMATELY MID-DAY
- 6 VIEW OF ON-SITE SUBSTATION AND EXITING OVERHEAD POWER LINES VIA BUS BARS AT THE SUBSTATION
- 7 TYPICAL BATTERY ENERGY STORAGE SYSTEM
- 8 VIEW FROM THE R556 LOOKING OVER THE MCGREGOR NATURE RESERVE

1 INTRODUCTION

1.1 GENERAL

This Landscape and Visual Impact Scoping stage study forms part of the Scoping and Environmental Impact Assessment that is being undertaken for the proposed establishment of a Ndau Solar PV 1 project with up to 120MW on Portion 19 of the Farm Rietvley No. 13, 27km south-west of Polokwane within Limpopo Province by Praxos 373 (Pty) Ltd on behalf of ABO Ndau Solar Energy Facility 1 (Pty) Ltd.

Ndau Solar PV 1 project is one of three projects being considered in the vicinity. The other projects include:

- Ndau Solar PV 2 project: and
- Ndau Battery Energy Storage (BESS).

The other two projects will be subject to separate applications.

In terms of the amended National Environmental Management Act (NEMA) Act No. 107 of 1998, the proposed development requires environmental authorisation. A key impact to be assessed comprises the visual impact that the facility will have on surrounding areas.

This Landscape and Visual Impact Assessment Baseline Report has been prepared for inclusion in the project Environmental Impact Assessment Scoping Report.

1.2 PROJECT LOCATION

The geographic co-ordinates of the proposed solar project (approximately center of the site) are:

Latitude	Longitude
24° 03' 02.90" S	29° 13' 21.44" E

The abovementioned property is indicated on the Site location Plan (**Map 1**).

1.3 BACKGROUND OF SPECIALIST

Jon Marshall qualified as a Landscape Architect in 1978. He has also had extensive experience of environmental impact assessment processes in South Africa. He has been involved in Visual Impact Assessment over a period of more than 30 years. He has developed the necessary computer skills to prepare viewshed analysis and three dimensional modelling to illustrate impact assessments. He has undertaken landscape and visual impact assessments for major buildings, industrial developments, mining, infrastructure projects and numerous renewable energy projects.

A brief Curriculum Vitae outlining relevant projects is included as **Appendix I**.

1.4 THE NATURE OF VISUAL IMPACT

Visual impacts may relate to a general change in the character of an area or in the change in a specific view for a person or group of people.

Visual impacts can be positive or negative and a degree of subjectivity is required in deciding this point. The approach of any visual assessment should, as objectively as possible, describe a landscape and as far as is possible reflect the likely majority view regarding positive / negative aspect of an impact. This can be difficult particularly in

South Africa due to different values and cultures associated with various sectors of the population. For example, poorer and particularly rural based sectors of the population are possibly more concerned with the productive nature of a landscape than its appearance, whereas the wealthier sectors might be more concerned with scenic value particularly as it is associated with property values. If possible, the values and opinions of all impacted sectors of the community should be considered.

General change to a landscape might have greater or lesser significance subject to;

- a) Numbers of people that might use the landscape,
- b) The use of the landscape,
- c) The level of protection afforded the landscape,
- d) The rarity of the landscape.

In terms of change to a specific view this might be defined as either visual intrusion or visual obstruction.

- a) Visual intrusion is a change in a view of a landscape that reduces the quality of the view. This can be a highly subjective judgement, subjectivity has been removed as far as is possible in this assessment by classifying the landscape character of each area and providing a description of the change in the landscape that will occur due to the proposed development.
- b) Visual obstruction is the blocking of views or foreshortening of views. This can generally be measured in terms of extent.

More often than not such an impact will be a combination of intrusion and obstruction. Obstruction can be measured in terms of the extent of an existing view that is screened by a development. However, judging intrusion requires a degree of subjectivity. It is however possible to relate this judgement to the manner in which proposed change would impact on the use or enjoyment of an area which again requires an understanding of local values.

1.5 RELEVANT GUIDELINES

Work is to be undertaken in accordance with the following guideline documents;

- a. The Government of the Western Cape Guideline for Involving Visual and Aesthetic Specialists in EIA Processes (Western Cape Guideline), which is the only local relevant guideline, setting various levels of assessment subject to the nature of the proposed development and surrounding landscape (**Appendix II**), and
- b. The Landscape Institute and Institute of Environmental Management and Assessment (UK) Guidelines for Landscape and Visual Impact Assessment which provides detail of international best practice (UK Guidelines).

Together, these documents provide a basis for the level and approach of a VIA as well as the necessary tools for assessment and making an assessment legible to stakeholders.

In addition to the above, this document complies with Appendix 6 of the EIA Regulations which lists requirements of Specialist Reports, see schedule below.

Regulation GNR 326 of 4 December 2014, as amended 7 April 2017, Appendix 6	Section of Report
1. (1) A specialist report prepared in terms of these Regulations must contain-	1
a) details of-	
i. the specialist who prepared the report; and	
ii. the expertise of that specialist to compile a specialist report including a curriculum vitae;	
b) a declaration that the specialist is independent in a form as may be specified by the competent authority;	Separate document.
c) an indication of the scope of, and the purpose for which, the report was prepared;	1
(cA) an indication of the quality and age of base data used for the specialist report;	1
(cB) a description of existing impacts on the site, cumulative impacts of the proposed development and levels of acceptable change;	6
d) the date and season of the site investigation and the relevance of the season to the outcome of the assessment;	1
e) a description of the methodology adopted in preparing the report or carrying out the specialised process inclusive of equipment and modelling used;	1
f) details of an assessment of the specific identified sensitivity of the site related to the proposed activity or activities and its associated structures and infrastructure, inclusive of a site plan identifying site alternatives;	6
g) an identification of any areas to be avoided, including buffers;	none
h) a map superimposing the activity including the associated structures and infrastructure on the environmental sensitivities of the site including areas to be avoided, including buffers;	Maps 4
i) a description of any assumptions made and any uncertainties or gaps in knowledge;	1
j) a description of the findings and potential implications of such findings on the impact of the proposed activity, (including identified alternatives on the environment) or activities;	6 and 7
k) any mitigation measures for inclusion in the EMPr;	To be completed during the assessment stage
l) any conditions for inclusion in the environmental authorisation;	To be completed during the assessment stage
m) any monitoring requirements for inclusion in the EMPr or environmental authorisation;	To be completed during the assessment stage

n) a reasoned opinion- i. whether the proposed activity, activities or portions thereof should be authorised; (iA) regarding the acceptability of the proposed activity or activities; and ii. if the opinion is that the proposed activity, activities or portions thereof should be authorised, any avoidance, management and mitigation measures that should be included in the EMP, and where applicable, the closure plan;	To be completed during the assessment stage
o) a description of any consultation process that was undertaken during the course of preparing the specialist report;	none
p) a summary and copies of any comments received during any consultation process and where applicable all responses thereto; and	none
q) any other information requested by the competent authority.	none
2) Where a government notice <i>gazetted</i> by the Minister provides for any protocol or minimum information requirement to be applied to a specialist report, the requirements as indicated in such notice will apply.	1

1.6 SCOPING OBJECTIVES

This Scoping Study identifies and evaluates potential environmental impacts associated with all aspects of the proposed Project. In terms of the EIA Regulations, feasible and reasonable alternatives should be assessed within the Scoping Study. The scope of an environmental assessment is defined by the range of issues and feasible alternatives to be considered, and the approach towards the assessment that will follow.

The characteristics of a scoping exercise are as follows:

- a) Feasible and reasonable alternatives are identified and selected for further assessment;
- b) Important characteristics of the affected environment are identified;
- c) Significant issues that are to be examined in the assessment procedure are identified; and
- d) It provides the basis for determining terms of reference for the assessment procedure.

1.7 LIMITATIONS AND ASSUMPTIONS

A site visit was undertaken over a single day period (13th May 2023) to verify the likely visibility of the proposed development, the nature of the affected landscape and affected receptors.

The site visit was planned to ensure that weather conditions were clear ensuring reasonable visibility.

The timing of photography was planned to ensure that the sun was as far as possible behind the photographer. This was to ensure that as much detail as possible was recorded in the photographs.


Visibility of the proposed facility has been assessed using the Global Mapper Viewshed tool.

The visibility assessment is based on terrain data that has been derived from satellite imagery. This data was originally prepared by NASA and is freely available on the CIAT-CCAFS website (<http://www.cgiar-csi.org>). This data has been ground truthed using a GPS as well as online mapping.

Calculation of visibility is based purely on the Digital Elevation Model and does not take into account the screening potential of vegetation or other development.

The following GIS data sets were used in undertaking and presenting the assessment:

DATA SET	SOURCE	YEAR
South Africa Protected Areas Database (SAPAD)	Department of Environmental Affairs	2021
SRTM Worldwide Elevation Data	CIAT-CCAFS	2018
World Imagery	ESRI	2009 (updated 2021)
SA NLC (National Land Cover)	Department of Environmental Affairs	2018
1:50,000 raster mapping	Chief Directorate National Geo-Spatial Information of South Africa	Unknown
South African rivers in drainage region ALL	Department of Water Affairs	2012
Update of vegm2009	South African National Biodiversity Institute	2015
South Africa /Lesotho Roads	Open Street Map	2014



2. PROJECT DESCRIPTION

2.1 PROJECT COMPONENTS

Infrastructure associated with Ndau Solar Energy Facility 1 will include the following:

- Solar Field/Solar Arrays (Note that the foundations, mounting structures and module types would be confirmed during detail design, however, would remain within the proposed development footprint and be up to approximately 3.5m in height);
- Internal access roads (noting that existing farm roads would be used as far as possible, and that the maximum road width would be up to approximately 10m);
- A main access road (noting that existing farm roads would be used as far as possible, and the road width would be up to approximately 10m);
- Internal electrical reticulation (i.e., low- and medium voltage lines) to be placed underground where feasible;
- An on-site substation hub and associated infrastructure (such as substation, transformation infrastructure, collector infrastructure, step-up infrastructure, battery energy storage system etc.) including auxiliary buildings (such as operation & maintenance buildings, admin buildings, workshops, gatehouse, security building, offices, visitor centre, warehouses, etc.) contained within up to approximately a **5 ha** footprint; and
- Perimeter fencing.

A temporary laydown area would be established during the construction period but would be within the development footprint i.e., within the fenced area allocated for development. The laydown area would move as required while construction is underway.

The proposed facility would be accessed from the north via an existing unnamed road. The detailed design of the proposed access and road upgrade requirements would be as per the recommendations of the Transport Impact Assessment which is being undertaken as part of the environmental impact assessment process.

Application for grid connection will be made through a separate process and assessed accordingly. An on-site grid connection to integrate into the national network via a 132 kV or 275 kV line is under consideration.

The operations of the proposed facility would require some servicing, noting that the operational electrical requirements would be nominal and would be supplied by the facility.

The following alternatives are under consideration:

1. Technology: With regard to the proposed BESS, the technology thereof is dynamic and so the specific type/technology to be developed would be selected based on market demands and technology availability at the time of construction. Therefore, both Lithium-ion and redox-flow are

assessed as technology alternatives, with Lithium-ion being the current preferred technology.

The No-go alternative will also be assessed.

2.2 OVERVIEW OF SOLAR PV TECHNOLOGY

Solar energy facilities, such as those which utilise PV technology use the energy from the sun to generate electricity through a process known as the **Photovoltaic Effect**. Generating electricity using the Photovoltaic Effect is achieved through the use of the following components:

Photovoltaic Modules

PV cells are made of crystalline silicon, the commercially predominant PV technology, that includes materials such as polycrystalline and monocrystalline silicon or thin film modules manufactured from a chemical ink compound. PV cells are arranged in multiples / arrays and placed behind a protective glass sheet to form a PV module (Solar Panel). Each PV cell is positively charged on one side and negatively charged on the opposite side, with electrical conductors attached to either side to form a circuit. This circuit captures the released electrons in the form of an electric current (i.e. Direct Current (DC)). When sunlight hits the PV panels free electrons are released and flow through the panels to produce direct electrical (DC) current.




Figure 1: Overview of a typical/generic PV cell, module, and array/panel, noting that the photograph on the right appears to depict a single axis tracking mount, but it is not clear from the angle of the photograph. Whether these depict mono- or bi- facial modules is also unclear (pveducation.com).

Inverters

Inverters are used to convert electricity produced by the PV panels from Direct Current (DC) into Alternating Current (AC), to enable the facility to be connected to the national electricity grid. In order to connect a large solar facility such as the one being proposed to the national electricity grid, numerous inverters will be arranged in several arrays to collect, and convert power produced by the facility.

Support Structures

PV panels will be fixed to a support structure. PV panels can either utilise fixed / static support structures, or alternatively they can utilise single or double axis tracking support structures. PV panels which utilise fixed / static support structures are set at an angle (fixed-tilt PV system) so as to optimise the

amount of solar irradiation. With fixed / static support structures the angle of the PV panel is dependent on the latitude of the proposed development and may be adjusted to optimise for summer and winter solar radiation characteristics. PV panels which utilise tracking support structures track the movement of the sun throughout the day so as to receive the maximum amount of solar irradiation.




Figure 2: Overview of different PV tracking systems (from left to right: fixed-tilt, single-axis tracking, and double-axis tracking (Source: pveducation.com)).

PV panels are designed to operate continuously for more than 20 years and with low maintenance.

On Site Electrical Infrastructure Compound:

An on-site electrical infrastructure compound typically comprises of a substation and associated infrastructure and could include additional collector infrastructure and / or a Battery Energy Storage System (BESS).

The on-site substation would serve as a collection point for the AC current from each inverter and includes step-up infrastructure (internal reticulation would be at low voltage, which would be stepped up by the sub-station for evacuation into the grid network / proposed collector sub-station) and typically it would be a maximum of 8m in height.

A substation can have circuit breakers that are used to switch generation and transmission circuits in and out of service as needed or for emergencies requiring shutdown of power to a circuit or redirection of power.

The need for a BESS stems from the fact that electricity is only produced by the Renewable Energy Facility while the sun is shining, while the peak demand may not necessarily occur during the daytime. Therefore, the storage of electricity and supply thereof during peak-demand will mean that the facility is more efficient, reliable and electricity supply more constant.

The BESS will store and integrate a greater amount of renewable energy from the Solar PV Facilities into the electricity grid. This will assist with the objective to generate electricity by means of renewable energy to feed into the National Grid via relevant available procurement programs applicable at the time.

2.3 THE LIKELY NATURE OF VIEWS OF THE PROPOSED PROJECT

The elements that are likely to be most visually obvious include the solar array and the electrical infrastructure compound.

2.3.1 Solar Array

Continuous supports aligned in rows are generally used when the PV panels are fixed and are set at an angle and direction to maximise the average efficiency during the day or have a basic tracking set up that varies the angle of tilt of the unit in order to improve efficiency.

From areas to the north a solar array, whether constructed on individual supports or continuous rows, is likely to appear as a continuous structure in the landscape.

The nature of the impact is also likely to vary with location and elevation;

- If the array is located on a hillside or if it is viewed from a higher level, the rows of PV units are likely to visually combine and will be read as a single unit. From a distance this results in a PV array having a similar appearance as a large industrial structure when viewed from above. It should be noted that the proposed project will not be viewed from a higher elevation and so this type of view will not apply;
- From the north and if the project is viewed from a similar level, the front row of PV units will be seen in elevation. This is likely to result in the project being seen as a continuous dark line in the landscape possibly with slightly higher elements such as the on-site electrical infrastructure compound extending above the line. How prominent the dark line is, is likely to be dependent on the distance of the viewer from the project as well as the extent to which the view of the elevation is broken by other elements such as vegetation and landform.
- From the south, east and west the dark face of the PV units is not obvious and subject to the colour of the undersides of the units, the supporting structures are likely to become more apparent. With distance however, the shadow cast by the structures is likely to be more obvious and the facility will probably appear much as the northern face, a long dark structure.
- If the landscape does not have significant Visual Absorption Capacity (VAC), because of the contrast in colour with the surrounding landscape, the array could be visible to the limit of visibility. Subject to the colour and reflectivity of the underside of the PV units and supporting structure, it is possible that a similar level of impact could also be experienced from the south, east and west. It should be noted that the VAC of the landscape surrounding the proposed development is largely dependent on minor ridgelines.
- Mitigation or screening of views is possible at least from close views. This can be achieved either by earthworks berms by planting or by a combination of both. From a distance and particularly from elevated viewpoints as views over screening may be possible and excessively tall

screening is likely to be less feasible as the it is likely to cast shadow over the PV units.

- In addition to the way that a solar array may change a landscape, the nuisance factor associated with resulting glare is often raised by stakeholders on similar projects. PV units, however, are designed to absorb as much energy as possible and are designed not to reflect light. This issue is generally more likely to be associated with a focussed array which tracks the sun's path during the day and uses reflective surfaces to focus energy onto receptors. It is therefore not expected that this will be a significant issue with a PV array such as the one proposed.

Due to relatively dense and consistent vegetation cover, the landscape has relatively high VAC which is likely to mean that the proposed development will be largely screened from surrounding areas.

Where it is visible however, because the site and surrounding area is relatively flat. the array is likely to be largely viewed either in elevation or at an acute elevated view from minor ridgelines.

A new solar array has been developed adjacent to Upington Airport. This array has been developed in two sections on either side of the airport runway. It is probably somewhat smaller than the subject project, covering approximately 25ha and the longest edge of the array being approximately 500m long. The PV panels are mounted on fixed frames approximately 2m high. Despite obvious differences compared with the proposed project, it does illustrate the effect of distance in mitigating the visibility of the solid line of solar panels.

Plate 1 indicates the location of the existing array at Upington Airport. **Plates 2, 3 and 4**, illustrate how the array is seen from distances of approximately 700m, 1500m and 5000m respectively.

The pictured project has solar panels approximately 2.0m high. The proposed project will have solar panels approximately 3.5m high which will increase their visibility.

The following effects are noted:

- From 700m the array is clearly visible. For the same effect relative to a 5.0m high array, this distance will be approximately 1225m.
- From 1500m, the array is visible but even with the minimal vegetation providing screening at the airport, the dark line of panels is starting to blend into the background. The array is visible but might be missed by a casual viewer. For the same effect relative to a 5.0m high array, this distance will be approximately 2625m.
- From 5000m, the line of panels is indistinguishable from the horizon. For the same effect relative to a 5.0m high array, this distance will be approximately 8750m.

These images provide an indication of potential levels of impact relative to the height and distance of the viewer from the facility.

Should a tracking array be used the height of panels will vary during the day. **Plate 5** indicates a single axis tracking array with panels lying flat at approximately mid-day. At this point in time the panels are approximately half the height that they would be early in the morning or late in the afternoon.



Plate 1, Existing solar arrays at Upington Airport as seen from the air



Plate 2, Existing array seen in a flat landscape from approximately 700m. The array is clearly visible.



Plate 3, Existing array seen in a flat landscape from approximately 1500m. The array is visible but even with the minimal vegetation providing screening at the airport, the dark line of panels is starting to blend into the background. The array is clearly visible but might be missed by a casual viewer who was not aware of its existence.



Plate 4, Existing array seen in a flat landscape from approximately 5000m. The line of panels is barely distinguishable. The viewer would have to know where to look to be able to differentiate the array from surrounding landscape features.



Plate 5, A single axis tracking solar PV project in the North West Province (Bokamoso Solar PV Plant) photographed at approximately mid-day

Note: solar panels are almost lying flat.

2.3.2 The Electrical Infrastructure Compound

The main elements of the on-site Substation that may have visual implications include:

- A security fence line which typically will be a steel palisade or mesh fence approximately 3m high;
- Transformers that will be used to step the power up for evacuation to the grid. These are likely to be large solid structures in the order of 5m high.
- Buildings to house control and switching infrastructure, stores, restrooms and staff facilities. These are likely to be single storey buildings up to approximately 6m high.
- Security lighting which is likely to be mounted on masts surrounding the compound. These are likely to be in the order of 10m high.
- Bus bars that will support the outgoing power transmission lines in order that they can link to the national grid. These are likely to be comprised of a steel tower structure in the order of 8m high.

The various elements can therefore be divided into:

- Lower transparent and opaque elements up to approximately 5-6m high including the security fence, buildings, and transformers; and
- Taller relatively transparent elements up to approximately 8m high including bus bars, and lighting towers.



Plate 6, View of on-site substation and exiting overhead power lines via Bus Bars at the substation

Because of their visual mass, the lower elements are likely to be highly visible whereas taller more transparent elements (Bus Bars) are not likely to be as visible over a distance. The relative slenderness and colouring (galvanised grey) of taller infrastructure have a major effect in reducing visibility to the

human eye. This is likely to significantly modify the ALV of the various elements of the proposed project.

The BESS will appear as a series of structures within which the battery infrastructure will be contained. The BESS structures could be in the order of 5m high.



Plate 8 - Typical Battery Energy Storage System

2.4 VISUAL LIMITS


From the analysis of likely visibility of elements in 2.3, the following visual limits have been adopted in order to provide an initial study area:

ELEMENT	APPROXIMATE LIMIT OF VISIBILITY (ALV)
Solar Array, up to 2.1m high	5.2 kilometres
Lower relatively opaque substation and BESS infrastructure, up to 6.0m high	10.1 kilometres

With the exception of the higher substation elements limits, the ALVs indicated above are highlighted on assessment mapping.

the visual limit for the higher sections of the substation will be within the other limits. It is therefore not critical at this stage in the definition of the study area.

These limits have been calculated using a recognised mathematical formula (**Appendix III**).



3. DESCRIPTION OF RECEIVING ENVIRONMENT AND RECEPTORS

It is possible that landscape change due to the proposed development could impact the character of the surrounding landscape. Landscape character can be derived from specific features relating to the urban or rural setting and may include key natural, historic or culturally significant elements. Importance might also relate to landscapes that are uncommon or under threat from development.

This section will;

- describe the types of landscapes that may be impacted: and
- indicate likely degree of sensitivity .

3.1 LANDSCAPE CHARACTER

Landscape character is defined as "a distinct, recognisable and consistent pattern of elements in the landscape that makes one landscape different from another"¹.

Landscape character has been defined using a desk top assessment using existing data sets and aerial photography as well as from knowledge of the area.

The affected area has a strong rural character, interspersed with agriculture and industrial activities particularly mining, and settlement.

Landscape Character is a composite of a number of influencing factors including;

- Landform and drainage
- Nature and density of development
- Vegetation patterns

3.1.1 Landform and Drainage

Refer to Map 3 for analysis of the landform and drainage.

The proposed site is located close to a watershed that runs in an approximate south-east to north-west direction. The watershed is marked by a range of hills that rise approximately 440m from 1480m amsl which is the approximate elevation of the site to approximately 1920m amsl which is the approximate elevation of the highest peak.

The proposed site is located on the north-east side of the watershed.

A series of minor ridgelines and valleys run in a general south-west to north-east direction from the watershed. The proposed site is located on one of these ridgelines.

¹ UK Guidelines

Watercourses to the north-east include the perennial Bloed and Sand Rivers as well as the non-perennial Stydomsloop. These watercourses drain through the minor valleys towards the north-east within an area of gently undulating topography between two major ridgelines.

The topography falls gently to the north.

The proposed site is located on an area of relatively high ground between two water courses. The Leragne is a perennial water course that is located approximately 2.6km to the west of the site and the Molapongwamongana is a non-perennial that flows approximately 4.0km to the east of the proposed site.

Topography has been significantly changed in areas by the addition of mine dumps. There is a large mine dump located close and to the south of the proposed site.

Visual implications of topography include:

- The higher land to the south-west will screen views of the proposed development from that direction.
- The fact that the site is located on a ridgeline could mean that the proposed development may be visible from the valley areas either side of the ridgeline as well as other adjacent ridgelines.

3.1.2 Landcover

Refer to Map 4 for analysis of Landcover.

The proposed site is located within an area of relatively natural landcover types.

Natural woodland covers the southern section of the site and extends south to the southern side of the N1.

Fallow land covers the northern section of the proposed site and covers areas to the north, east and west. This landcover type is generally comprised of regenerating woodland species.

Natural grassland generally covers the high land to the south-west and forms a matrix with natural forest for much of the area within the ALV to the north of the site.

Commercial cultivation extends in a band to the north-east of the proposed site. This is mixed with patches of natural forest as well as fallow land.

There are also four protected areas in the vicinity including:

- **The Percy Fyfe Nature Reserve** which is located approximately 1.8km to the north- west of the proposed site;
- **The Mogoto Private Nature Reserve** which is located approximately 4.5km to the south of the proposed site;
- **The Kuschke Nature Reserve** which is located approximately 10.5km to the east of the proposed site; and
- **The H L Crause Private Nature Reserve** which is located approximately 8.1km to the west of the proposed site.

Infrastructure includes:

- The N1 Freeway which is a major strategic route that links Gauteng with Polokwane and areas to the north. The N1 is important for business, logistics and for tourism as it links business and tourism destinations in the north to Gauteng;
- The R101 which is a key local distributor. This route is probably more important for local people than the N1, however, it will also no doubt carry tourist traffic particularly people visiting local lodges.
- High voltage overhead power lines including the 400kV Matimba / Witkop powerline and the 275kV Warmbad / Witkop powerline.

There are also numerous homesteads scattered throughout the area. These are generally associated with agricultural operations, however, there are also homesteads within natural areas which are possibly associated with game farming and / or tourist accommodation or lodges.

Visual implications of landcover include:

- The largely woodland, grassland and fallow land in the vicinity of the proposed site provides a relatively natural setting;

3.1.3 Vegetation Patterns

Natural Vegetation within the study area is comprised of Polokwane Plateau Bushveld². This vegetation type is characterised by moderately undulating plains with short open tree layer with a well-developed grass layer to grass plains with occasional trees at higher altitudes.

Homestead Vegetation is largely comprised of a mix of alien and indigenous tree species with a mix of ornamental shrub vegetation. It also includes vegetable production

Arable cropping occurs in small areas in the vicinity of the proposed site. The main commercial crops include maize and vegetables. There are also small areas of subsistence farming which largely includes vegetable production.

Visual implications include;

- The natural areas in the vicinity of the proposed site help to create an over-riding natural landscape character;
- Where Bushveld occurs, the small trees in the vegetation matrix could provide significant screening.
- Other vegetation types are likely to create an open landscape where screening may only be provided by topography or development.

² Mucina and Rutherford

3.2 LANDSCAPE CHARACTER AREAS & VISUAL ABSORPTION CAPACITY


Landscape Character Areas (LCAs) are defined as “single unique areas which are the discrete geographical areas of a particular landscape type”³.


Visual Absorption Capacity (VAC) is defined as the landscape's ability to absorb physical changes without transformation in its visual character and quality. Where elements that contrast with existing landscape character are proposed, VAC is dependent on elements such as landform, vegetation and other development to provide screening of a new element. The scale and texture of a landscape is also critical in providing VAC, for example; a new large scale industrial development located within a rural small scale field pattern is likely to be all the more obvious due to its scale.

The affected landscape can be broadly divided into the following LCAs that are largely defined by landuse:

- **Natural Landscape Character Area** which is comprised of the undulating valley areas and the high land that forms the watershed. The low tree cover on the valley slopes provides significant screening. This LCA includes protected areas;
- **Cleared and Cultivated LCA** which is comprised of areas of arable agriculture. Crops are generally low providing little or no enclosure or screening;

³ Landscape Institute & Institute of Environmental Management and Assessment





LANDSCAPE CHARACTER AREAS



NATURAL LCA



CLEARED AND CULTIVATED LCA

3.3 LANDSCAPE QUALITY AND IMPORTANCE

The landscape in the vicinity of the proposed site is relatively natural. This is important for the game farms and lodges in the area that depend on the natural landscape to rear animals and draw tourists.

There are a number of protected areas located close to the proposed site. These areas have significant importance for biodiversity, tourism and local recreation.

3.4 VISUAL RECEPTORS

3.4.1 Definition

Visual Receptors are defined as “individuals and / or defined groups of people who have the potential to be affected by the proposal”⁴.

Certain areas are also sensitive due to an existing use. The nature of an outlook is generally more critical to areas that are associated with recreation, tourism and in areas where outlook is critical to land values.

3.4.2 Visual receptors

The following visual receptors were noted from the site visit:

Area Receptors:

Area receptors are places that cannot be defined by a point or a line. They might include settlements or protected areas. From the site visit possible area receptors include:

- Protected areas particularly the Percy Fyfe Nature Reserve which is within 1.8km of the proposed site.

Linear Receptors:

Linear receptors generally include routes through the area:

- Local Roads that are generally un-surfaced roads that link the area to the R101 south of the proposed site and to the south-east close to Mokopane.
- The RN1 and the R101 both of which run parallel to the south of the proposed site. The N1 is the closer of the two roads being located approximately 500m from the site.

Point Receptors,

Point receptors include isolated, homesteads most of which are likely to be associated with agriculture, however, a number are likely to have a tourism use (Lodges) particularly those within more natural areas.

3.5 LIKELY SENSITIVITY OF LCA'S AND RECEPTORS

The sensitivity of receptors to likely changes in view due to the proposed development is partly subjective. However, in order to provide clarity for the assessment, the following table indicates the manner in which sensitivities have been considered in the assessment.

Landscape Sensitivity Criteria

SIGNIFICANCE	LCA	RECEPTORS
Low	Landscape value is not recognised or the landscape is very tolerant of change. These areas include: <ul style="list-style-type: none">• Cleared and Cultivated LCA.	Small number or low sensitivity of viewers assumed. Viewers' attention not focused on landscape. These include: <ul style="list-style-type: none">• People visiting and travelling through the area for business, work,

⁴ Landscape Institute & Institute of Environmental Management and Assessment

		and commercial reasons on local and main roads.
Medium	Landscape value is recognised locally but is not protected; the landscape is relatively intact, with a distinctive character; and the landscape is reasonably tolerant of change. These areas include:	Viewer's attention may be generally focused on the landscape. These include: <ul style="list-style-type: none"> • Homesteads • People visiting and travelling through the area for recreational / tourism reasons on main and local roads.
High	Landscape value recognised by existing or proposed national or regional designation. Sense of tranquillity or remoteness specifically noted in Landscape Character Assessment. High sensitivity to disturbance. The qualities for which the landscape is valued are in a good condition, with a clearly apparent distinctive character. This distinctive character is susceptible to relatively small changes. These areas include: <ul style="list-style-type: none"> • Natural LCA. 	Viewer's attention very likely to be focused on the landscape. e.g. users of public rights of way and access land, strategic recreational footpaths; people experiencing views from important landscape features of physical, cultural or historic interest, beauty spots and picnic areas. Large number of viewers and/or location in highly valued landscape could elevate viewer sensitivity to highest level. These include: <ul style="list-style-type: none"> • Visitors to protected areas.

POSSIBLE VISUAL RECEPTORS



MAIN ROADS (N1)



PROTECTED AREAS



HOMESTEADS



LOCAL ROADS

4 SITE SENSITIVITY

The review of the proposed project indicates that the following issues need to be considered during site planning and assessment.

The screening tool indicated that the proposed site may be sensitive. This is probably due to the proximity of the proposed site to the Percy Fyfe Nature Reserve. From the site visit and from an initial viewshed analysis it was found that the proposed development will not be visible from the reserve. Because of this the site sensitivity is unlikely to be highly sensitive as indicated on the DFFE screening tool. Our assessment below indicates that it is likely to have a site sensitivity rating of low to medium.

4.1 NO GO DEVELOPMENT AREAS

The directly affected landscape is neither protected nor is it rare so from a landscape perspective there are no no-go areas.

4.2 SITE DEVELOPMENT SENSITIVITY

Sensitivity to development relates to:

- Guiding development away from areas of the site that would make it most obvious to surrounding sensitive receptors.

Highly Sensitivity Areas include:

There are no areas of high sensitivity

Medium Sensitivity Areas include:


Medium sensitivity areas include areas include:

- the ridgeline that bisects the site as development of this area is likely to extend the range of visibility and could make the project visible from Percy Fyfe Nature Reserve; and
- the south facing slope as development of this area is likely to create a risk of the project being visible from the N1.

Low Sensitivity Areas include:

Medium sensitivity areas include areas include:

- the north facing slope as development of this area is unlikely to be visible to sensitive receivers.



5 IDENTIFICATION AND INITIAL ASSESSMENT OF ISSUES

5.1 IMPACTS TO BE CONSIDERED

Possible impacts identified include:

- a) Potential change to the landscape;
- b) Potential visual impacts as experienced by travellers on local roads in close proximity to the proposed site;
- c) Potential visual impacts as experienced by travellers on Main roads in close proximity to the proposed site;
- d) Potential visual impacts as experienced by residents and visitors to homesteads and lodges;
- e) Potential visual impacts as experienced by residents and visitors to protected areas.

Subject to the proposed layout and the visibility of the proposed project, these issues will be considered in the context of possible degradation of Landscape Character Areas, visual effects identified and possible cumulative influence of other possible projects that exist or are planned in the vicinity.

At this stage of the project, there is no indication of the proposed layout. Possible impacts can therefore only be discussed at a generic level.

5.2 SIGNIFICANCE OF ISSUES

Sensitivity mapping provides an indication of the likelihood of significant issues; however, without an indication of the possible location and layout of the project, it is not possible to be confident regarding the significance of impacts.

5.3 INITIAL ASSESSMENT OF ISSUES

5.3.1 Landscape Change

Potential Impact			
Issue	Nature of Impact	Extent of Impact	No-Go Areas
Further general degradation of the local landscape	<p><u>Direct impacts:</u> increase in industry and loss of natural landscape.</p> <p>The project will marginally increase the area of industry in the area and reduce the area of natural vegetation. However, due to its location and screening provided by landform and small trees the proposed project is unlikely to be highly obvious to surrounding areas.</p>	Local	None identified at this stage

	<u>Indirect impacts:</u> No indirect impacts		
Description of expected significance of impact			
The landscape in the vicinity of the proposed site is relatively natural. The project is likely to result in loss of natural areas.			
Gaps in knowledge & recommendations for further study			
Detailed Assessment.			
Recommendations with regards to general field surveys			
Assessing the extent of change that will be obvious.			

5.3.2 Main Roads

Potential Impact			
Issue	Nature of Impact	Extent of Impact	No-Go Areas
Degradation of views from the N1 in proximity to the proposed site. Only this short section of road may be affected.	<u>Direct impacts:</u> Loss of views of natural landscape. <u>Indirect impacts:</u> No indirect impacts	Local	None identified at this stage
Description of expected significance of impact			
Only the N1 is likely to be impacted.			
The existing small trees between the proposed site and the N1 will help to screen the project from the road. Their retention and possible augmentation is therefore critical.			
Risk may be reduced further through ensuring that development is kept off the ridgeline.			
If this mitigation is followed, the significance of the impact is likely to be low.			
Gaps in knowledge & recommendations for further study			
Detailed Assessment.			
Recommendations with regards to general field surveys			
None.			

5.3.3 Local Roads

Potential Impact

Issue	Nature of Impact	Extent of Impact	No-Go Areas
Further degradation of the local landscape as viewed from adjacent local roads	<u>Direct impacts:</u> Further industrialisation of views from local roads. <u>Indirect impacts:</u> No indirect impacts	Local	None identified at this stage
<p>Description of expected significance of impact</p> <p>Only the local road that runs approximately 1.5km to the east is likely to be affected. The property between the proposed project and this road has well developed natural vegetation including small trees. This vegetation currently screens sections of the proposed site from the road.</p> <p>As long as bordering natural vegetation is retained, the visual impact of the proposed development is likely to be partially screened / softened from the road.</p> <p>The significance of any impact is therefore anticipated to be low.</p>			
<p>Gaps in knowledge & recommendations for further study</p> <p>Detailed Assessment.</p> <p>Recommendations with regards to general field surveys</p> <p>Assessing the extent of change that will be obvious.</p>			

5.3.4 Homesteads

Potential Impact			
Issue	Nature of Impact	Extent of Impact	No-Go Areas
Further degradation of the local landscape as viewed from homesteads	<u>Direct impacts:</u> Industrialisation of views from homesteads. <u>Indirect impacts:</u> No indirect impacts	Local	None identified at this stage
<p>Description of expected significance of impact</p> <p>The closest homestead is approximately 1km to the north-east of the proposed site. This homestead is used for tourist accommodation (Ysterberg Lodge).</p> <p>The buildings are all set amongst trees so it is possible that views over the site from accommodation may not be possible. However, it is likely that views of the site will be possible from the property.</p>			

Development of the northern slope and ridgeline is likely to be visible to open areas around buildings. Development of the ridge is likely to be most visible.

As long as development of the ridgeline is minimised, the significance of any impact is anticipated to be low.

Gaps in knowledge & recommendations for further study

Detailed Assessment.

Recommendations with regards to general field surveys

Assessing the extent of change that will be obvious.

5.3.5 Protected Areas

Potential Impact			
Issue	Nature of Impact	Extent of Impact	No-Go Areas
Degradation of views from the Percy Fyfe Nature Reserve.	<u>Direct impacts:</u> Possible reflection from solar panels. <u>Indirect impacts:</u> No indirect impacts	Local	None identified at this stage
<p>Description of expected significance of impact</p> <p>Only the Percy Fyfe Nature Reserve is likely to be impacted.</p> <p>As long as development is kept off the ridgeline the risk of impact is relatively small.</p> <p>Risk relates to views of the panels / substation as well as reflection from the panel faces making them more obvious than they otherwise would be.</p> <p>Risk of reflection may be reduced through the use of a tracking system and an anti-glare coating on panel faces.</p> <p>Only a small area of the reserve could possibly be affected.</p> <p>If mitigation as described is used, the significance of any impact is anticipated to be low.</p>			
<p>Gaps in knowledge & recommendations for further study</p> <p>None.</p>			
<p>Recommendations with regards to general field surveys</p> <p>None.</p>			

5.3.6 Lighting

Potential Impact

Issue	Nature of Impact	Extent of Impact	No-Go Areas
Lighting Impacts.	<u>Direct impacts:</u> Light pollution affecting adjacent roads and homesteads. <u>Indirect impacts:</u> No indirect impact.	Local	None identified at this stage
<p>Description of expected significance of impact</p> <p>Lighting is likely to be required for security, maintenance and the safety / convenience of workers.</p> <p>It is possible to mitigate lighting impacts to a large degree through design, the use of motion sensors for security lighting and ensuring that lighting is only used in areas where workers are located / working.</p> <p>Homesteads are in excess of 1km from the proposed project. With careful design to minimise light spill, this should be sufficient distance to ensure that nuisance impacts are minimal.</p> <p>If suitable mitigation measures are used, it is unlikely that lighting impacts will be significant.</p>			
<p>Gaps in knowledge & recommendations for further study</p> <p>Confirmation of the nature of proposed lighting.</p> <p>Recommendations with regards to general field surveys</p> <p>Assess existing levels of impact.</p>			

6 RECOMMENDED ASSESSMENT METHODOLOGY

6.1 REQUIREMENTS IN ACCORDANCE WITH THE WESTERN CAPE GUIDELINES

The criterion recommended by the Western Cape Guidelines for justification of level of input for a VIA is the expected level of visual impact. This categorisation is derived from the following matrix;

Type of environment	Type of development (see Box 3) Low to high intensity				
	Category 1 development	Category 2 development	Category 3 development	Category 4 development	Category 5 development
Protected/wild areas of international, national, or regional significance	Moderate visual impact expected	High visual impact expected	High visual impact expected	Very high visual impact expected	Very high visual impact expected
Areas or routes of high scenic, cultural, historical significance	Minimal visual impact expected	Moderate visual impact expected	High visual impact expected	High visual impact expected	Very high visual impact expected
Areas or routes of medium scenic, cultural or historical significance	Little or no visual impact expected	Minimal visual impact expected	Moderate visual impact expected	High visual impact expected	High visual impact expected
Areas or routes of low scenic, cultural, historical significance / disturbed	Little or no visual impact expected. Possible benefits	Little or no visual impact expected	Minimal visual impact expected	Moderate visual impact expected	High visual impact expected
Disturbed or degraded sites / run-down urban areas / wasteland	Little or no visual impact expected. Possible benefits	Little or no visual impact expected. Possible benefits	Little or no visual impact expected	Minimal visual impact expected	Moderate visual impact expected

Category 1 development:

e.g. nature reserves, nature-related recreation, camping, picnicking, trails and minimal visitor facilities.

Category 2 development:

e.g. low-key recreation / resort / residential type development, small-scale agriculture / nurseries, narrow roads and small-scale infrastructure.

Category 3 development:

e.g. low density resort / residential type development, golf or polo estates, low to medium-scale infrastructure.

Category 4 development:

e.g. medium density residential development, sports facilities, small-scale commercial facilities / office parks, one-stop petrol stations, light industry, medium-scale infrastructure.

Category 5 development:

e.g. high density township / residential development, retail and office complexes, industrial facilities, refineries, treatment plants, power stations, wind energy farms, power lines, freeways, toll roads, large-scale infrastructure generally. Large-scale development of agricultural land and commercial tree plantations. Quarrying and mining activities with related processing plants.

From reference to the categorisation of development included in the Western Cape Guidelines as indicated in the table above, the proposed development if standing on its own should be considered as a Category 4 development.

Based on the predicted visual impacts described in this report, and on the basis that the proposed new facility, it seems likely that the proposed development is likely to have minimal landscape and visual impact.

Due to the anticipated low levels of impact, it is recommended that a Level 3 Input is undertaken. Should significant issues be identified during the assessment stage, the input may be elevated to Level 4.

Level 3 input requires the following;

- Identification of issues raised in scoping phase, and site visit;
- Description of the receiving environment and the proposed project;
- Establishment of view catchment area, view corridors, viewpoints and receptors;
- Indication of potential visual impacts using established criteria;
- Inclusion of potential lighting impacts at night;
- Description of alternatives, mitigation measures and monitoring programmes.
- Review by independent, experienced visual specialist (if required).

Level 4 input requires the same as Level 3 plus 3D modeling with and without mitigation.

6.2 DETAILED METHODOLOGY

As indicated above, confirmation of the following is required in order to investigate and finalise the issues and impacts highlighted by this initial LVIA scoping exercise:

- a) Confirmation of the layout of the facility.

The following methodology will be used in preparation of the LVIA report.

6.2.1 Identification of issues raised in scoping phase, and site visit

Likely issues have already been identified in this scoping analysis. These issues will be verified from a site visit as well as responses from stakeholders to the scoping documentation.

It is possible that additional impacts might be identified from the site visit and from comments by stakeholders.

6.2.2 Description of the receiving environment and the proposed project

The receiving environment has been described and categorised. This will be verified from a site visit.

6.2.3 Establishment of view catchment area, view corridors, viewpoints and receptors

Zones of theoretical visibility will be prepared and visual receptors have been established from GIS analysis. These will be verified from a site visit. Existing large scale industrial development should help to provide a useful guide as to likely visibility of the proposed development.

Viewpoints will be identified from a site visit to represent views of visual receptors.

6.2.4 Indication of Potential Visual Impacts using Established Criteria

Given that the existing landscape character is a relatively cohesive rural landscape, it will be assumed that affected receptors are likely to prefer views of a rural landscape rather than an industrial landscape

Criteria will include:

- The extent of likely industrialisation as seen by each receptor; and
- The sensitivity of each receptor to change.

Impacts will be assessed using a numerical assessment system that has been adopted by Savannah Environmental for the overall EIA assessment.

6.2.5 Inclusion of Potential Lighting Impacts at night

This will be assessed through comparison of the likely change in night time lighting patterns due to the proposed development.

6.2.6 Description of Alternatives, Mitigation Measures and Monitoring Programme

This will be compiled from experience of similar projects and through discussion with the applicant.

REFERENCES

Guidelines for involving visual and aesthetic specialists in EIA processes,

Author; Bernard Oberhozer. Published by the Provincial Government of the Western Cape: Department of Environmental Affairs and Development Planning, 2005

Guidelines for landscape and visual impact assessment (third edition), authors; the Landscape Institute and Institute of Environmental Assessment and Management, published by E & FN Spon, 2013.

The vegetation of South Africa, Lesotho and Swaziland(Strelitzia series; no. 19), Mucina, L. & Rutherford, M.C. (eds.), 2006, South African National Biodiversity Institute, Pretoria.

Best Management Practices for Reducing Visual Impacts of Renewable Energy Facilities on BLM Administered Lands *United States Department of the Interior, Bureau of Land Management, 2013.*

Appendix 6, EIA Regulations (2014) as amended, promulgated under section 24 of the National Environmental Management Act, 107 of 1998. Department of Forestry Fisheries and the Environment.

APPENDIX I
ASSESSOR'S CURRICULUM VITAE



ENVIRONMENTAL PLANNING AND DESIGN

Name	JONATHAN MARSHALL
Nationality	British
Year of Birth	1956
Specialisation	Landscape Architecture / Landscape & Visual Impact Assessment / Environmental Planning / Environmental Impact Assessment.
Qualifications	
<u>Education</u>	Diploma in Landscape Architecture, Gloucestershire College of Art and Design, UK (1979) Environmental Law, University of KZN (1997)
<u>Professional</u>	Registered Professional Landscape Architect (SACLAP) Chartered Member of the Landscape Institute (UK)
Languages	<u>English</u> - Speaking - Excellent - Reading - Excellent - Writing - Excellent
Contact Details	Post: 13 Askew Grove Glenwood Durban 4001 Cell: +27 83 7032995

General

Jon qualified as a Landscape Architect (Dip LA) at Cheltenham (UK) in 1979. He has been a chartered member of the Landscape Institute UK since 1986. He is also a Registered Landscape Architect and has had extensive experience of Environmental Assessment within South Africa.

During the early part of his career (1981 - 1990) He worked with Clouston (now RPS) in Hong Kong and Australia. During this period he was called on to undertake visual impact assessment (VIA) input to numerous environmental assessment processes for major infrastructure projects. This work was generally based on photography with line drawing superimposed to illustrate the extent of development visible.

He has worked in the United Kingdom (1990 - 1995) for major supermarket chains including Sainsbury's and prepared CAD based visual impact assessments for public enquiries for new store development. He also prepared the VIA input to the environmental statement for the Cardiff Bay Barrage for consideration by the UK Parliament in the passing of the Barrage Act (1993).

His more recent LVIA work (1995 to present) includes a combination of CAD and GIS based work for a new international airport to the north of Durban, new heavy industrial operations, overhead electrical transmission lines, mining operations in West Africa and numerous commercial and residential developments.

VIA work undertaken during the last twelve months includes wind energy projects, numerous solar plant projects (CSP and PV) and electrical infrastructure.

Select List of Landscape & Visual Impact Assessment Projects

- **Coega Power Ship** – Landscape and Visual Impact Assessment for the proposed Coega Power Ship project in the Eastern Cape Province.
- **Saldanha Power Ship** - Landscape and Visual Impact Assessment for the proposed Coega Power Ship project in the Western Cape Province.
- **Modderfontein Wind Energy Facility** - Landscape and Visual Impact Assessment for a proposed amendment to the layout and wind turbine specification of a previously authorised project near Beaufort West.
- **Western Cape Wind Energy Facility** – Due diligence assessment for a proposed wind energy facility near Swellendam in the Western Cape Province.
- **Hyperion Thermal Generation Facility** - Landscape and Visual Impact Assessment for a proposed gas powered power generation plant near Kathu in the Northern Cape Province.
- **Beachfront House on ERF 766 Scarborough** - Landscape and Visual Impact Assessment for a proposed development of beachfront house on the edge of the Table Mountain National Park in Scarborough, Western Cape Province.
- **Springs Special Economic Zone** - Landscape and Visual Impact Assessment for the proposed Springs SEZ in the Gauteng Province.
- **Makapanstad Agri- Hub** – Landscape and Visual Impact Assessment for proposed Agri-Hub development at Makapanstad in the North West Province for the Department of Rural Development and Land Reform.
- **Madikwe Sky Bubble** - Landscape and Visual Impact Assessment for proposed development of up-market accommodation at the Molori concession within the Madikwe Game Reserve.
- **Hartebeest Wind Energy Facility** – Landscape and Visual Impact Assessment Addendum Report for the proposed upgrading of turbine specifications for an authorised WEF near MoOrreesburg in the Western Cape Province for a private client.
- **Selati Railway Bridge** - Landscape and Visual Impact Assessment for proposed development of up-market accommodation on a railway bridge at Skukuza in the Kruger Park.
- **Kangala Mine Extension** - Landscape and Visual Impact Assessment for a proposed extension to the Kangala Mine in Mpumalanga for Universal Coal.
- **Khunab Solar Developments** – Landscape and Visual Impact Assessment for four proposed solar PV projects near Upington in the Northern Cape Province for a private client.
- **Sirius Solar Developments** – Landscape and Visual Impact Assessment for four proposed solar PV projects near Upington in the Northern Cape Province for Sola Future Energy.
- **Aggeneys Solar Developments** – Landscape and Visual Impact Assessment for two proposed solar PV projects near Aggeneys in the Northern Cape Province for a private client.
- **Hyperion Solar Developments** – Landscape and Visual Impact Assessment for four proposed solar PV projects near Kathu in the Northern Cape Province for Building Energy South Africa.
- **Eskom Combined Cycle Power Plant** - Landscape and Visual Impact Assessment for proposed gas power plant in Richards Bay, KwaZulu Natal Province.
- **N2 Wild Coast Toll Road, Mineral Sources and Auxiliary Roads** – LVIA for the Pondoland Section of this project for the South African National Roads Agency.
- **Mpushini Park Ashburton** – LVIA for a proposed amendment to an authorised development plan which included residential, office park and light industrial uses to logistics and warehousing.
- **Moedeng PV Solar Project** - LVIA for a solar project near Vryburg in the North West Province for a private client.
- **Establishment of Upmarket Tourism Accommodation on the Selati Bridge, Kruger National Park**

– Assessment of visual implications of providing tourism accommodation in 12 railway carriages on an existing railway bridge at the Skukuza Rest Camp in the Kruger Park.

- **Jozini TX Transmission Tower** – Assessment of visual implications of a proposed MTN transmission tower on the Lebombo ridgeline overlooking the Pongolapoort Nature reserve and dam.
- **Bhangazi Lake Development** – LVIA for a proposed tourism development within the iSimangaliso Wetland Park World Heritage Site.
- **Palesa Power Station** - LVIA for a new 600MW power station near Kwamhlanga in Mpumalanga for a private client.
- **Heuningklip PV Solar Project** – LVIA for a solar project in the Western Cape Province for a private client.
- **Kruispad PV Solar Project** – LVIA for a solar project in the Western Cape Province for a private client.
- **Doornfontein PV Solar Project** – LVIA for a solar project in the Western Cape Province for a private client.
- **Olifantshoek Power Line and Substation** – LVIA for a new 10MVA 132/11kV substation and 31km powerline, Northern Cape Province, for Eskom.
- **Noupoort Concentrating Solar Plants** - Scoping and LVIAs for two proposed parabolic trough projects.
- **Drakensberg Cable Car** – Preliminary LVIA and draft terms of reference as part of the feasibility study.
- **Paulputs Concentrating Solar Plant (tower technology)** – LVIA for a new CSP project near Pofadder in the Northern Cape.
- **Ilanga Concentrating Solar Plants 1, 2, 3, 4 & 5** – Scoping and LVIAs for the proposed extension of five authorised CSP projects including parabolic trough and tower technology within the Karoshoek Solar Valley near Upington in the Northern Cape.
- **Ilanga Concentrating Solar Plants 1, 2, 3, 4 & 5 Shared Infrastructure** –LVIA for the necessary shared infrastructure including power lines, substation, water pipeline and roads for these projects.
- **Ilanga Concentrating Solar Plants 7, 8 & 9** - Scoping and LVIAs for three new CSP projects including parabolic trough and tower technology within the Karoshoek Solar Valley near Upington in the Northern Cape.
- **Sol Invictus Solar Plants** - Scoping and LVIAs for three new Solar PV projects near Pofadder in the Northern Cape.
- **Gunstfontein Wind Energy Facility** – Scoping and LVIA for a proposed WEF near Sutherland in the Northern Cape.
- **Moorreesburg Wind Energy Facility** – LVIA for a proposed WEF near Moorreesburg in the Western Cape.
- **Semonkong Wind Energy Facility** - LVIA for a proposed WEF near Semonkong in Southern Lesotho.
- **Great Karoo Wind Energy Facility** – Addendum report to the Visual Impact Assessment Report for amendment to this authorised WEF that is located near Sutherland in the Northern Cape. Proposed amendments included layout as well as rotor diameter.
- **Perdekraal East Power Line** – LVIA for a proposed power line to evacuate power from a wind energy facility near Sutherland in the Northern Cape.
- **Tshivhaso Power Station** – Scoping and LVIA for a proposed new power station near Lephalale in Limpopo Province.
- **Saldanha Eskom Strengthening** – Scoping and LVIA for the upgrading of strategic Eskom infrastructure near Saldanha in the Western Cape.
- **Eskom Lethabo PV Installation** - Scoping and LVIA for the development of a solar PV plant within Eskom's Lethabo Power Station in the Free State.

- **Eskom Tuthuka PV Installation** - Scoping and LVIA for the development of a solar PV plant within Eskom's Thutuka Power Station in Mpumalanga.
- **Eskom Majuba PV Installation** - Scoping and LVIA for the development of a solar PV plant within Eskom's Majuba Power Station in Mpumalanga.
- **Golden Valley Power Line** - LVIA for a proposed power line to evacuate power from a wind energy facility near Cookhouse in the Eastern Cape.
- **Mpophomeni Shopping Centre** – LVIA for a proposed new shopping centre close to the southern shore of Midmar Dam in KwaZulu Natal.
- **Rheboksfontein Power Line** - Addendum report to the Visual Impact Assessment Report for amendment to this authorised power line alignment located near Darling in the Western Cape.
- **Woodhouse Solar Plants** – Scoping and LVIA for two proposed solar PV projects near Vryburg in the North West Province.
- **AngloGold Ashanti, Dokiwa (Ghana)** – LVIA for proposed new Tailings Storage Facility at a mine site working with SGS as part of their EIA team.
- **Gateway Shopping Centre Extension (Durban)** – LVIA for a proposed shopping centre extension in Umhlanga, Durban.
- **Kouroussa Gold Mine (Guinea)** – LVIA for a proposed new mine in Guinea working with SGS as part of their EIA team.
- **Mampon Gold Mine (Ghana)** - LVIA for a proposed new mine in Ghana working with SGS as part of their EIA team.
- **Telkom Towers** – LVIA for numerous Telkom masts in KwaZulu Natal.
- **Eskom Isundu Substation** – LVIA for a proposed major new Eskom substation near Pietermaritzburg in KwaZulu Natal.
- **Eskom St Faiths Power Line and Substation** – LVIA for a major new substation and associated power lines near Port Shepstone in KwaZulu Natal.
- **Eskom Ficksburg Power Line** – LVIA for a proposed new power line between Ficksburg and Cocolan in the Free State.
- **Eskom Matubatuba to St Lucia Power Line** – LVIA for a proposed new power line between Mtubatuba and St Lucia in KwaZulu Natal.
- **Dube Trade Port, Durban International Airport** – Landscape & Visual Impact Assessment.
- **Sibaya Precinct Plan** – LVIA as part of Environmental Impact Assessment for a major new development area to the north of Durban.
- **Umdloti Housing** – LVIA as part of Environmental Impact Assessment for a residential development beside the Umdloti Lagoon to the north of Durban.
- **Tata Steel Ferrochrome Smelter** - LVIA of proposed new Ferrochrome Smelter in Richards Bay as part of EIA undertaken by the CSIR.
- **Durban Solid Waste Large Landfill Sites** – LVIA of proposed development sites to the North and South of the Durban Metropolitan Area. The project utilised 3d computer visualisation techniques.
- **Hillside Aluminium Smelter, Richards Bay** - LVIA of proposed extension of the existing smelter. The project utilised 3d computer visualisation techniques.
- **Estuaries of KwaZulu Natal Phase 1** – Visual character assessment and GIS mapping as part of a review of the condition and development capacity of eight estuary landscapes for the Town and Regional Planning Commission. The project was extended to include all estuaries in KwaZulu Natal.
- **Signage Assessments** – Numerous impact assessments for proposed signage developments for Blast Media.

- **Signage Strategy** – Preparation of an environmental strategy report for a national advertising campaign on National Roads for Visual Image Placements.
- **Zeekoegatt, Durban** - EDP acted as advisor to the Province of KwaZulu Natal in an appeal brought about by a developer to extend a light industrial development within a 60 metre building line from the National N3 Highway.
- **La Lucia Mall Extension** - LVIA using three dimensional computer modelling / photo realistic rendering and montage techniques for proposed extension to shopping mall for public consultation exercise.
- **Redhill Industrial Development** - LVIA assessment using three dimensional computer modelling / photo realistic rendering and montage techniques for proposed new industrial area for public consultation exercise.
- **Avondale Reservoir** - LVIA using three dimensional computer modelling / photo realistic rendering and montage techniques for proposed hilltop reservoir as part of Environmental Impact Assessment for Umgeni Water.
- **Hammersdale Reservoir** - LVIA using three dimensional computer modelling / photo realistic rendering and montage techniques for proposed hilltop reservoir as part of Environmental Impact Assessment for Umgeni Water.
- **Southgate Industrial Park, Durban** - LVIA and Landscape Design for AECI.
- **Sainsbury's Bryn Rhos** - Computer Aided Landscape & Visual Impact Assessment/ Planning Application for the development of a new store within the Green Wedge North of Swansea.
- **Ynyston Farm Access** - Computer Aided Landscape & Impact Assessment of visual intrusion of access road to proposed development of Cardiff for the Land Authority for Wales.
- **Cardiff Bay Barrage** – Preparation of the Visual Impact Statement for inclusion in the Impact Statement for debate by parliament (UK) prior to the passing of the Cardiff Bay Barrage Bill.
- **A470, Cefn Coed to Pentrebach** - Preparation of landscape frameworks for the assessment of the impact of the proposed alignment on the landscape for The Welsh Office.
- **Sparkford to Illchester Bye Pass** - The preparation of the landscape framework and the draft landscape plan for the Department of Transport.
- **Green Island Reclamation Study** - Visual Impact Assessment of building massing, Urban Design Guidelines and Masterplanning for a New Town extension to Hong Kong Island.
- **Route 3** - Visual Impact Assessment for alternative road alignments between Hong Kong Island and the Chinese Border.
- **China Border Link** - Visual Impact Assessment and initial Landscape Design for a new border crossing at Lok Ma Chau.
- **Route 81, Aberdeen Tunnel to Stanley** - Visual Impact Assessment for alternative highway alignments on the South side of Hong Kong Island.

APPENDIX II

GUIDELINES FOR INVOLVING VISUAL AND AESTHETIC SPECIALISTS IN EIA PROCESSES

**(Preface, Summary and Contents for full document go to the Provincial
Government of the Western Cape, Department of Environmental Affairs and
Development Planning web site, [http://eadp.westerncape.gov.za/your-resource-
library/policies-guidelines](http://eadp.westerncape.gov.za/your-resource-library/policies-guidelines))**

GUIDELINE FOR INVOLVING VISUAL AND AESTHETIC SPECIALISTS IN EIA PROCESSES



PROVINCIAL GOVERNMENT OF THE WESTERN CAPE:
DEPARTMENT OF ENVIRONMENTAL AFFAIRS
AND DEVELOPMENT PLANNING



CSIR

Edition 1
June 2005

GUIDELINE FOR INVOLVING VISUAL AND AESTHETIC SPECIALISTS IN EIA PROCESSES

Edition 1

Issued by:

Provincial Government of the Western Cape
Department of Environmental Affairs and Development Planning
Utilitas Building, 1 Dorp Street
Private Bag X9086
Cape Town 8000
South Africa

Prepared by:

Bernard Oberholzer Landscape Architect
PO Box 26643
Hout Bay, 7872, South Africa
email: bola@wol.co.za

Coordinated by:

CSIR Environmentek
P O Box 320
Stellenbosch 7599
South Africa

Contact person:

Frauke Münster
Tel: +27 21 888-2538
(fmunster@csir.co.za)

COPYRIGHT © Republic of South Africa, Provincial Government of the Western Cape, Department of Environmental Affairs and Development Planning 2005. ALL RIGHTS RESERVED.

This document is copyright under the Berne Convention. Apart from the purpose of private study, research or teaching, in terms of the Copyright Act (Act No. 98 of 1978) no part of this document may be reproduced or transmitted in any form or by any means, electronic or mechanical, including photocopying, recording or by any information storage and retrieval system, without permission in writing from the Department of Environmental Affairs and Development Planning. Likewise, it may not be lent, resold, hired out or otherwise disposed of by way of trade in any form of binding or cover other than that in which it is published.

This guideline should be cited as:

Oberholzer, B. 2005. *Guideline for involving visual & aesthetic specialists in EIA processes: Edition 1*. CSIR Report No ENV-S-C 2005 053 F. Republic of South Africa, Provincial Government of the Western Cape, Department of Environmental Affairs & Development Planning, Cape Town.

ACKNOWLEDGEMENTS

Steering committee:

Paul Hardcastle	-	DEA&DP
Ayub Mohammed	-	DEA&DP
Susie Brownlie	-	de Villiers Brownlie Associates
Keith Wiseman	-	City of Cape Town
Mike Burns	-	CSIR Environmentek
Paul Lochner	-	CSIR Environmentek
Pete Ashton	-	CSIR Environmentek

Focus group participants:

Paul Hardcastle	-	DEA&DP
Washiela Anthony	-	DEA&DP
Danie Smit	-	DEAT
Eileen Weinronk	-	City of Cape Town
Menno Klapwijk	-	Cave Klapwijk and Associates
Graham Young	-	Landscape Consultant
Bernard Oberholzer	-	Bernard Oberholzer Landscape Architect (BOLA)
Nicolas Baumann	-	Baumann & Winter Heritage Consultants
Sarah Winter	-	Baumann & Winter Heritage Consultants
Tanya de Villiers	-	Chittenden Nicks deVilliers Africa
Frauke Münster	-	CSIR Environmentek

Internal review:

Mike Burns	-	CSIR Environmentek
Eileen Weinronk	-	City of Cape Town
Paul Hardcastle	-	DEA&DP
Washiela Anthony	-	DEA&DP

Stakeholders engaged in the guideline development process:

These guidelines were developed through a consultative process and have benefited from the inputs and comments provided by a wide range of individuals and organizations actively working to improve EIA practice. Thanks are due to all who took the time to engage in the guideline development process.

In particular, thanks are due to Jan Glazewski (University of Cape Town), Keith Wiseman (City of Cape Town), Paul Britton (SANPARKS), Graham Young (University of Pretoria), Lisa Parkes (Ninham Shand) and Paul Claassen (Environomics) for providing useful information and in-depth comments.

Finalisation of report figures and formatting:

Magdel van der Merwe and Elna Logie, DTP Solutions

PREFACE

The purpose of an Environmental Impact Assessment (EIA) is to provide decision-makers (be they government authorities, the project proponent or financial institutions) with adequate and appropriate information about the potential positive and negative impacts of a proposed development and associated management actions in order to make an informed decision whether or not to approve, proceed with or finance the development.

For EIA processes to retain their role and usefulness in supporting decision-making, the involvement of specialists in EIA needs to be improved in order to:

- Add greater value to project planning and design;
- Adequately evaluate reasonable alternatives;
- Accurately predict and assess potential project benefits and negative impacts;
- Provide practical recommendations for avoiding or adequately managing negative impacts and enhancing benefits;
- Supply enough relevant information at the most appropriate stage of the EIA process to address adequately the key issues and concerns, and effectively inform decision-making in support of sustainable development.

It is important to note that not all EIA processes require specialist input; broadly speaking, specialist involvement is needed when the environment could be significantly affected by the proposed activity, where that environment is valued by or important to society, and/or where there is insufficient information to determine whether or not unavoidable impacts would be significant.

The purpose of this series of guidelines is to improve the efficiency, effectiveness and quality of specialist involvement in EIA processes. The guidelines aim to improve the capacity of roleplayers to anticipate, request, plan, review and discuss specialist involvement in EIA processes. Specifically, they aim to improve the capacity of EIA practitioners to draft appropriate terms of reference for specialist input and assist all roleplayers in evaluating whether or not specialist input to the EIA process is appropriate for the type of development and environmental context. Furthermore, they aim to ensure that specialist inputs support the development of effective, practical Environmental Management Plans where projects are authorised to proceed (refer to *Guideline for Environmental Management Plans*).

The guidelines draw on best practice in EIA in general, and within specialist fields of expertise in particular, to address the following issues related to the timing, scope and quality of specialist input. The terms “specialist involvement” and “input” have been used in preference to “specialist assessment” and “studies” to indicate that the scope of specialists’ contribution (if required) depends on the nature of the project, the environmental context and the amount of available information and does not always entail detailed studies or assessment of impacts.

The guidelines draw on best practice in EIA in general, and within specialist fields of expertise in particular, to address the following issues related to the timing, scope and quality of specialist input. The terms “specialist involvement” and “input” have been used in preference to “specialist

assessment” and “studies” to indicate that the scope of specialists’ contribution depends on the nature of the project, the environmental context and the amount of available information.

	ISSUES
TIMING	<ul style="list-style-type: none"> ▪ When should specialists be involved in the EIA process; i.e. at what stage in the EIA process should specialists be involved (if at all) and what triggers the need for their input?
SCOPE	<ul style="list-style-type: none"> ▪ Which aspects must be addressed through specialist involvement; i.e. what is the purpose and scope of specialist involvement? ▪ What are appropriate approaches that specialists can employ? ▪ What qualifications, skills and experience are required?
QUALITY	<ul style="list-style-type: none"> ▪ What triggers the review of specialist studies by different roleplayers? ▪ What are the review criteria against which specialist inputs can be evaluated to ensure that they meet minimum requirements, are reasonable, objective and professionally sound?

The following guidelines form part of this first series of guidelines for involving specialists in EIA processes:

- Guideline for determining the scope of specialist involvement in EIA processes
- Guideline for the review of specialist input in EIA processes
- Guideline for involving biodiversity specialists in EIA processes
- Guideline for involving hydrogeologists in EIA processes
- Guideline for involving visual and aesthetic specialists in EIA processes
- Guideline for involving heritage specialists in EIA processes
- Guideline for involving economists in EIA processes

The *Guideline for determining the scope of specialist involvement in EIA processes* and the *Guideline for the review of specialist input in EIA processes* provide generic guidance applicable to any specialist input to the EIA process and clarify the roles and responsibilities of the different roleplayers involved in the scoping and review of specialist input. It is recommended that these two guidelines are read first to introduce the generic concepts underpinning the guidelines which are focused on specific specialist disciplines.

Who is the target audience for these guidelines?

The guidelines are directed at authorities, EIA practitioners, specialists, proponents, financial institutions and other interested and affected parties involved in EIA processes. Although the guidelines have been developed with specific reference to the Western Cape province of South Africa, their core elements are more widely applicable.

What type of environmental assessment processes and developments are these guidelines applicable to?

The guidelines have been developed to support project-level EIA processes regardless of whether they are used during the early project planning phase to inform planning and design decisions (i.e. during pre-application planning) or as part of a legally defined EIA process to obtain statutory approval for a proposed project (i.e. during screening, scoping and/or impact assessment). Where specialist input may be required the guidelines promote early, focused and appropriate involvement of specialists in EIA processes in order to encourage proactive consideration of potentially significant impacts, so that negative impacts may be avoided or

effectively managed and benefits enhanced through due consideration of alternatives and changes to the project.

The guidelines aim to be applicable to a range of types and scales of development, as well as different biophysical, social, economic and governance contexts.

What will these guidelines not do?

In order to retain their relevance in the context of changing legislation, the guidelines promote the principles of EIA best practice without being tied to specific legislated national or provincial EIA terms and requirements. They therefore do not clarify the specific administrative, procedural or reporting requirements and timeframes for applications to obtain statutory approval. They should, therefore, be read in conjunction with the applicable legislation, regulations and procedural guidelines to ensure that mandatory requirements are met.

It is widely recognized that no amount of theoretical information on how best to plan and coordinate specialist inputs, or to provide or review specialist input, can replace the value of practical experience of coordinating, being responsible for and/or reviewing specialist inputs. Only such experience can develop sound judgment on such issues as the level of detail needed or expected from specialists to inform decision-makers adequately. For this reason, the guidelines should not be viewed as prescriptive and inflexible documents. Their intention is to provide best practice guidance to improve the quality of specialist input.

Furthermore, the guidelines do not intend to create experts out of non-specialists. Although the guidelines outline broad approaches that are available to the specialist discipline (e.g. field survey, desktop review, consultation, modeling), specific methods (e.g. the type of model or sampling technique to be used) cannot be prescribed. The guidelines should therefore not be used indiscriminately without due consideration of the particular context and circumstances within which an EIA is undertaken, as this influences both the approach and the methods available and used by specialists.

How are these guidelines structured?

The specialist guidelines have been structured to make them user-friendly. They are divided into six parts, as follows:

- **Part A:** Background;
- **Part B:** Triggers and key issues potentially requiring specialist input;
- **Part C:** Planning and coordination of specialist inputs (drawing up terms of reference);
- **Part D:** Providing specialist input;
- **Part E:** Review of specialist input; and
- **Part F:** References.

Part A provides grounding in the specialist subject matter for all users. It is expected that authorities and peer reviewers will make most use of Parts B and E; EIA practitioners and project proponents Parts B, C and E; specialists Part C and D; and other stakeholders Parts B, D and E. Part F gives useful sources of information for those who wish to explore the specialist topic.

SUMMARY

This guideline document, which deals with specialist visual input into the EIA process, is organised into a sequence of interleading sections. These follow a logical order covering the following:

- the background and context for specialist visual input;
- the triggers and issues that determine the need for visual input;
- the type of skills and scope of visual inputs required in the EIA process;
- the methodology, along with information and steps required for visual input;
- finally, the review or evaluation of the visual assessment process.

Part A is concerned with defining the visual and aesthetic component of the environment, and with principles and concepts relating to the visual assessment process. The importance of the process being logical, holistic, transparent and consistent is stressed in order for the input to be useful and credible.

The legal and planning context within which visual assessments take place indicate that there are already a number of laws and bylaws that protect visual and scenic resources. These resources within the Western Cape context have importance for the economy of the region, along with the proclaimed World Heritage Sites in the Province.

The role and timing of specialist visual inputs into the EIA process are outlined, with the emphasis being on timely, and on appropriate level of input, from the early planning stage of a project, through to detailed mitigation measures and

management controls at the implementation stage.

Part B deals with typical factors that trigger the need for specialist visual input to a particular project. These factors typically relate to:

- (a) the nature of the receiving environment, in particular its visual sensitivity or protection status;
- (b) the nature of the project, in particular the scale or intensity of the project, which would result in change to the landscape or townscape.

The correlation between these two aspects are shown in a table, in order to determine the varying levels of visual impact that can be expected, i.e. from little or no impact, to very high visual impact potential.

Part C deals with the choice of an appropriate visual specialist, and the preparation of the terms of reference (TOR) for the visual input. Three types of visual assessment are put forward, each requiring different expertise, namely:

- Type A: assessments involving large areas of natural or rural landscape;
- Type B: assessments involving local areas of mainly built environment;
- Type C: assessments involving smaller scale sites with buildings, or groups of buildings.

The scope of the visual input would in summary relate to the following:

- the issues raised during the scoping process;
- the time and space boundaries, i.e. the extent or zone of visual influence;

- the types of development alternatives that are to be considered;
- the variables and scenarios that could affect the visual assessment;
- the inclusion of direct, indirect and cumulative effects.

Approaches to the visual input relate to the level of potential impact and range from minimal specialist input, to a full visual impact assessment (VIA). A list of the typical components of a visual assessment is given, and the integration with other studies forming part of the EIA process is discussed.

Part D provides guidance for specialist visual input, and on the information required by specialists. Notes on predicting potential visual impacts are given, along with suggested criteria for describing and rating visual impacts. The assessment of the overall significance of impacts, as well as thresholds of significance are discussed.

Further aspects that need to be considered by visual specialists in EIA processes include:

- affected parties who stand to benefit or lose,
- risks and uncertainties related to the project,
- assumptions that have been made, and their justification,
- levels of confidence in providing the visual input or assessment,
- management actions that can be employed to avoid or mitigate adverse effects and enhance benefits, and
- the best practicable environmental option from the perspective of the visual issues and impacts.

Finally, pointers for the effective communication of the findings are given.

Part E lists specific evaluation criteria for reviewing visual input by a specialist, where this becomes necessary. Further guidance on this is given in the document on *Guideline for the review of specialist input in EIA processes*.

CONTENTS

Acknowledgements	i
Preface	ii
Summary	v

PART A : BACKGROUND **1**

1. INTRODUCTION	1
2. PRINCIPLES AND CONCEPTS UNDERPINNING VISUAL SPECIALIST INVOLVEMENT IN EIA PROCESSES	2
3. CONTEXTUALISING SPECIALIST INPUT	4
3.1 Legal, policy and planning context for involving a visual specialist	5
3.2 Environmental context for specialist input	6
4. THE ROLE AND TIMING OF SPECIALIST INPUT WITHIN THE EIA PROCESS	6

PART B: TRIGGERS AND KEY ISSUES POTENTIALLY REQUIRING SPECIALIST INPUT **9**

5. TRIGGERS FOR SPECIALIST INPUT	9
6. KEY ISSUES REQUIRING SPECIALIST INPUT	10

PART C: PLANNING AND COORDINATION OF SPECIALIST INPUTS (DRAWING UP THE TERMS OF REFERENCE) **13**

7. QUALIFICATIONS, SKILLS AND EXPERIENCE REQUIRED	13
8. DETERMINING THE SCOPE OF SPECIALIST INPUTS	14
8.1 Identifying and responding to issues	15
8.2 Establishing appropriate time and space boundaries	16
8.3 Clarifying appropriate development alternatives	16
8.4 Establishing environmental and operating scenarios	17
8.5 Addressing direct, indirect and cumulative effects	17
8.6 Selecting the appropriate approach	18
8.7 Clarifying the timing, sequence and integration of specialist input	20
8.8 Ensuring appropriate stakeholder engagement	20
8.9 Clarifying confidentiality requirements	21

PART D: PROVIDING SPECIALIST INPUT	22
9. INFORMATION REQUIRED TO PROVIDE SPECIALIST INPUT	22
9.1 Relevant project information	22
9.2 Information describing the affected environment	23
9.3 Legal, policy and planning context	24
9.4 Information generated by other specialists in the EIA process	24
10. SPECIALIST INPUT TO IMPACT ASSESSMENT AND RECOMMENDING MANAGEMENT ACTIONS	25
10.1 Predicting potential impacts	25
10.2 Interpreting impact assessment criteria	26
10.3 Establishing thresholds of significance	29
10.4 Describing the distribution of impacts – beneficiaries and losers	30
10.5 Identifying key uncertainties and risks	30
10.6 Justifying underlying assumptions	31
10.7 Defining confidence levels and constraints to input	31
10.8 Recommending management actions	31
10.9 Identifying the best practicable environmental option	32
10.10 Communicating the findings of the specialist input	32
11. SPECIALIST INPUT TO MONITORING PROGRAMMES	33
PART E: REVIEW OF THE SPECIALIST INPUT	36
12. SPECIFIC EVALUATION CRITERIA	36
PART F: REFERENCES	37

APPENDIX III

FORMULA FOR DERIVING THE APPROXIMATE VISUAL HORIZON

The Mathematics behind this Calculation

This calculation should be taken as a guide only as it assumes the earth is a perfect ball 6378137 metres radius. It also assumes the horizon you are looking at is at sea level. A triangle is formed with the centre of the earth (C) as one point, the horizon point (H) is a right angle and the observer (O) the third corner. Using Pythagoras's theorem we can calculate the distance from the observer to the horizon (OH) knowing CH is the earth's radius (r) and CO is the earth's radius (r) plus observer's height (v) above sea level.

Sitting in a hotel room 10m above sea level a boat on the horizon will be 11.3km away. The reverse is also true, whilst rowing across the Atlantic, the very top of a mountain range 400m high could be seen on your horizon at a distance of 71.4 km assuming the air was clear enough.

