

Any person undertaking building operations in accordance with this plan is required to ascertain from the City Electrical Engineer the location of underground cables in the vicinity of the proposed works prior to the commencement thereof.

IMPORTANT
 APPLICATION FOR REFUND OF PORTION OF BUILDING FEES ON ABANDONED PLANS MUST BE RECEIVED BY THE CITY ENGINEER'S DEPARTMENT NOT LATER THAN THIRTY (30) DAYS AFTER THE EXPIRY DATE OF APPROVAL OF THIS PLAN.

Contractor to construct manhole No. 6... and then apply to D.C. for connection to be installed prior to commencing any further drainage work. Once connection is installed all drainage work to be graded to ensure entry to the connection as provided.

STORMWATER/SEWERAGE
 APPLICANT TO ENSURE CORRECT LEVEL OF ENTRY INTO D.C. DRAINS AND/OR CHANNELS AT APPROVED DISCHARGE POINTS

FRONTAGE LEVEL REQUIREMENTS
 Tops of foundations of any frontage works to be at least 0.230 m below the levels given below.
 Where no level is recorded, foundations shall not be higher than the nearest edge of the adjacent hardened road.
 Vehicular and pedestrian entrances on the road reserve boundary shall be constructed on the same grade as the kerb or road and shall either (A) conform to the existing kerb/verge OR (B) be at a level 0.200 m (i) above/below nearest existing kerb OR (ii) above/below the nearest edge of the hardened/unmade road.
 Date _____ Signature _____
 It is confirmed:—
 (A) Existing frontage level in order.
 (B) Existing frontage level NOT IN ORDER.
 (C) Undertaking form to be submitted.
 Date of Second Circulation _____ Signature _____

DIRECTOR: 45-042-17

CARPORY ALTS. TO EXIST. SEWER. LAYOUT:
Dr. A. KRAMER
 16 MARGARET MAYTON AVENUE, DURBAN NORTH.
 57 of 107 of 18 1987 J.C.
 CAT. No. 305280

HARRY TOUNTAS
 309B HIGHWAY HOUSE
 83 JAIN SMITHS HIGHWAY
 P.O. BOX 20214, DBN. NORTH
 4016 - PHONE 811588

REF.	DRAWN M.C.C.	DATE MAY 1983	SCALE 1:100
DRG No. 3861			SCALE 1:100

