

H4 Pinelands Office Park Maxwell Drive, Modderfontein Box 320, Modderfontein, 1645 Tel: (011) 201 4783/85

Website: www.ishecon.co.za Company Reg no. CK 99/29022/23

WSP for Enertrag Camden I and II Projects Building C, Knightsbridge, 33 Sloane St, Bryanston 082 786 7819 ashlea.strong@wsp.com Tel: (011) 201 4783/85 Fax: (086) 549 0878

E-mail: mitchelld@ishecon.co.za

Our Ref - J2893M-2

19 September, 2022

Dear Madam

RE: HIGH LEVEL SHE RA FOR CAMDEN I & II BESS AND GREEN HYDROGEN/AMMONIA COMPLEX

This letter serves to confirm that the proposed project, as below:

Emoyeni Renewable Energy Farm (Pty) Ltd is proposing the development of a commercial Wind Energy Facility and associated infrastructure on a site located ~6km south-east of Bethal and 1km east of Morgenzon, within the Mpumalanga Province. The project site is located across the Govan Mbeki, Lekwa, and Msukaligwa Local Municipalities within the Gert Sibande District (refer to Figure 1.1). The facility will have a contracted capacity of up to 666MW and will be known as the Ummbila Emoyeni Wind Energy Facility. The project is planned as part of a larger cluster of renewable energy projects (to be known as the Ummbila Emoyeni Renewable Energy Farm), which include one 666MW wind energy facility, to be developed in several phases, and one 150MW solar energy facility. The grid connection infrastructure for both facilities will include a 400/132kV Main Transmission Substation (MTS), to be located between the Camden and SOL Substations, which will be looped in and out of the existing Camden-Sol 400kV transmission line; on-site switching stations (132kV in capacity) at each renewable energy facility (Eskom Portion); 132kV power lines from the switching stations at each renewable energy facility to the new 400/132kV MTS; and a collector substation with 2 x 132kV bus bars and 4 x 132kV IPP feeder bays to the onsite IPP Substation.

...will not have any significant impact on the high level Safety Health and Environmental Risk Assessments conducted for the Camden I and Camden II projects (and vice versa). Therefore no change to the project reports is required.

Yours faithfully,

D C Mitchell Risk Assessor