



- NOTES:**
- REMOVE AND STOCKPILE TOPSOIL TO 200mm DEPTH
 - SERVICE TRENCH (SEE DETAILS) WITH ELECTRICAL CABLES AT BOTTOM AND FIBRE OPTIC CABLES ON TOP-COVERED WITH IMPORTED RIVER SAND (MIN 300mm AND BACKFILL)

				DESIGNED YM	 <p>Cnr. Rose/Havelock Street Central, Port Elizabeth, 6001 PO Box 5104 Walmer, 6065 Tel: +27 (41) 505-8000 Fax: +27 (41) 585-3437 info@afri-coast.co.za</p>	PROJECT DIRECTOR B.E	ROODEPLAAT WIND FARM PROPOSED TYPICAL ROAD CROSS SECTION	STATUS: PRELIMINARY	SCALE: 1:50
			CHECKED SS	PROJECT MANAGER H.N		DRAWING No: R1011-D02		REVISION: 0	
0	YM	PRELIMINARY	10/02/2015	DRAWN YM					
NO.	DRAWN	REVISION	DATE						