



Triplo4 Sustainable Solutions (Pty) Ltd

**Suite 5, The Circle, Douglas Crowe Drive
Ballito
KwaZulu Natal
4420**

Enquiries: L Stroh

Tel: 011 545 1232

Strohl@caa.co.za

03 May 2021

Ref. CAA_2021_1_080

Attention: Hantie Plomp

Conditional Approved of Proposed Power Plant, KPS Richards Bay.

After evaluating the site position to the obstacle application form dated 25 November 2020, in principle the SACAA has **no objection**, the following conditions and restrictions applies:

- Non-reflecting paint and materials should be applied to reduce glare and prevent blinding pilots.
- Caution be taken on any hot air/gasses as it has seriously effect on flying conditions of Aircraft,.
- Structure development is restricted to an all-inclusive, not exceeding height of 56.18m that include power lines (above ground level).
- Kindly note that approval for the construction of cranes, if used, must be obtained 6 weeks prior to construction.

The above statement is conditional to the developer, providing the SACAA with the "as built" parameters of the facility, which includes the height and final layout of building. The SACAA will provide a **final approval** on receipt of **details on "as built"**.

This conditional approval is valid for 5 years from the date of this letter.

Note that this SACAA letter of no objection does not substitute or replace other approvals which may be required by the applicant.

Yours truly,

A handwritten signature in black ink, appearing to read 'L Stroh'.

Lizell Stroh

Obstacle Inspector

PANS-OPS Section

Air Navigation Services Department

Tel: +27 11 545 1232 | Mobile: +27 083 461 6660

Email: Strohl@caa.co.za