ELECTRICITY SERVICES

Any person undertaking building operations in accordance with this plan is required to ascertain from the Executive Director, Electricity Department,

1) The location of any electrical services and servitudes in the vicinity of the proposed works
2) Departmental requirements regarding Substation, Meter rooms and Cable ducts.

A. As certified on the Application Form, the author of the plan is responsible for:-
(1) showing on the application drawings
(a) the correct level of entry into DC sewers, drains and/or channels or discharge points;
(b) the level of foundations of any frontage works at a minimum depth of 0.230 metres below frontage level;
(2) showing any encroachment over DC servitudes or DC underground services.

B. Frontage levels are:-
(1) to conform to the back of the constructed sidewalk, or
(2) to be calculated by the use of the following formula:-

$$FL = E + 0.150 m + \frac{D}{25}$$

(where FL = frontage level, E = level at edge of hardened road, and D = distance in metres between edge of road hardening and road reserve boundary.)

C. A concrete beam at the correct frontage level is to be provided at each entrance/exit at the same grade as the kerb or road.

D. No change in level over DC servitudes or DC underground services shall be made without the prior written approval of the City Engineer."

SUB. D. OF 4.

ADJ. RES.

SUB. C. OF 4

ADJ. RES.

SUB D

SUB 4.

SUB. 5.

SUB 2.

SUB. 13.

ADJ. BLG.

ADJ. BLG.

ADJ. BUILDING.

ADJ. BUILDING.

ADJ. BUILDING.

EX. RESIDENCE.

EX. GARAGES

EX. CARPORT.

EX. RETAINING WALL

EX. RETAINING WALL

EX. RETAINING WALL