


Appendix D4.1 Borehole Test Certificate



 **LEGACY** | ENVIRONMENTAL
MANAGEMENT
CONSULTING



22ND AVE 421
VILLIERIA
PRETORIA
ERNEST WRIGHT 073 646 2001
GUSTAV BOSMAN 072 561 0223
boorgatguru@gmail.com



BOREHOLE TEST CERTIFICATE

CLIENT INFORMATION

GAVIN

CONTACT DETAILS

082 881 4396

ADDRESS

MONAGENG RESORT

DINOKENG

TEST INFORMATION

DATE OF TEST:

24 MAY 2021

BOREHOLE NUMBER:

BH7

BOREHOLE POSITION:

25°16'41.5"S 28°21'03.7"E

DEPTH OF BOREHOLE:

110 METER

STATIC WATER LEVEL:

62.7 METER

DYNAMIC WATER LEVEL:

106 METER

DEPTH OF PUMP:

108 METER

TEST PUMP:

SVM200-23

RECOVERY:

N/A

HOURS TESTED:

4 HOURS

YIELD LPH:

6000 LITRES PER HOUR

EXISTING PUMP AND

CONDITION:

N/A

COMMENTS:

Ref No:

GA2105