



Environmental Consultants

ENVIRONMENTAL MANAGEMENT PROGRAMME (EMPr) – SUBSTATION CONDITIONS

DFFE National File Reference Number:

14/12/16/3/3/2/998

Project Title:

The proposed development of a 300MW solar photovoltaic (PV) facility on Portion 1 of Farm Riet Fountain 39C, Portion 1 of Kwanselaars Hoek 40C and Portion 4 of Taaibosch Fontein 41C in the Hanover district, Emthanjeni local municipality, Pixley Ka Seme district municipality; Northern Cape province.

Prepared for:



Applicant:

SolarAfrica Energy (Pty) Ltd

David MacDonald

Managing Director

49 Via Salara, Irene Corporate Corner,

Nellmapius Drive, Irene Farm Villages, Centurion, 0133

Tel: 012 881 4800

Cell: 072 729 9890

Email: david@solarafrica.com

Web: www.solarafrica.com/

Compiled by:

Ecoleges Environmental Consultants cc

Tel: +27 (0)83 644-7179

Fax: 086 697 9316

P.O. Box 9005, Nelspruit, 1200

P.O. Box 516, Machadodorp, 1170

Email: justin@ecoleges.co.za

Additional & site-specific substation conditions

MAINSTREAMING WILDLIFE INCIDENT MANAGEMENT INTO UTILITIES IN SOUTHERN AFRICA - GUIDELINE

Nest and perch deterrents designed specifically for substation hardware should also be used as preventative measures and established bird nests must be removed from substations.

Completely protect access to substations by small mammals through adequate perimeter (e.g.) electric fencing.