78 Thabile Engineering			
CK no: 2002/028096/23			Cash Asset Trading 32 CC trading as
٤	4 Pres Paul Kruger Avenue		PO Box 31446
	Park West		Fichardt Park
	Bloemfontein		9317
	9300		
	051 444 0480	~	051 444 0456
VAT. No:	4790201828		abrie@thabile.co.za

The Manager MDA PO Box 100982 BRANDHOF 9324 06 May 2016

Attention: Mr Neil Devenish

ELECTRICAL SERVICES REPORT FOR THE PROPOSED TRUCK STOP AND DIESEL DEPOT ON PORTION 5 OF THE FARM AVENHAM 2187.

The property falls within the Eskom supply area. At present there is an active 100 kVA, 400 volt Eskom supply point on the property. The owner and developer of the truck stop and diesel depot, Mr. Andre Smith, indicated that the existing supply will have sufficient capacity for the new development as is. It will also not be required to move the supply point to a more favourable location.

The existing supply point is in the name of Mr. JJ Knoetze and is in the process to be transferred to Mr Smith. The Eskom account number is 7511504386 and the pole designation is GSP 287/36/116/197/96/3.

We are therefore of the opinion that no extra work is required to ensure a secure supply for the new development. The LV reticulation, beyond the Eskom supply point, will be done by the developer and will have to meet the National and Eskom requirements as prescribed (SANS 10142-1).

Yours sincerely

J A Deacon (Pr.Eng, Pr. CPM, M.Eng (Elec))

for Thabile Engineering