

## **Appendix F:**

- General Authorisation from the Department of Water and Sanitation – see underneath.
  - SAHRA information (none),
- Service letters from municipalities – see underneath.
  - Water supply information (none).

- General Authorisation from the Department of Water and Sanitation.



## water & sanitation

Department:  
Water and Sanitation  
REPUBLIC OF SOUTH AFRICA

Vaal Proto CMA, 285 Francis Baard Street, Pretoria, Private Bag X995, Pretoria, 0001.

Tel (012) 3921300, Fax: 012 392 2998, [www.dwa.gov.za](http://www.dwa.gov.za).

**Enquiries:** Andrew Mbedzi  
**Email:** [mbedzia@dws.gov.za](mailto:mbedzia@dws.gov.za)  
**Cell:** 073-485-3497

**Tel:** 012-392-1479  
**Fax:** 086-274-3717  
**Ref no:** 27/2/2/C122/113/3

City of Johannesburg Metropolitan Municipality: Emdeni-Zola Public Transport Facility.  
PO Box 61877  
Marshalltown  
Johannesburg  
2107

Attention: Mrs. Nombuso Mtsweni.

**REGISTRATION OF WATER USE IN TERMS OF SECTION 39 OF THE NATIONAL WATER ACT, NO 36 OF 1998 (NWA): CITY OF JOHANNESBURG METROPOLITAN MUNICIPALITY: EMDENI-ZOLA PUBLIC TRANSPORT FACILITY, GAUTENG, WITHIN C22A QUARTENARY CATCHMENT VAAL WATER MANAGEMENT AREA.**

Your request dated 10 February 2020 to be registered to use water in terms of General Authorisation no. 509 dated 26 August 2016 refers:

The Department is pleased to confirm that the intended water use falls within the ambit of the General Authorisation. Therefore, you may continue with the water uses as permissible in terms of Section 22(1) (a) (iii) of the NWA. You are therefore requested to adhere to the conditions stipulated in the said General Authorisation.

Water use(s) registered:

**Section 21(c) of the NWA: Impeding or diverting the flow of water in a watercourse.**

**Section 21(i) of the NWA: Altering the bed, banks, course or characteristics of a watercourse.**



**NATIONAL DEVELOPMENT PLAN**  
*Our Future - make it work*

Table 1 water uses authorised

Water Resource Affected	Activity / Description	Properties	Footprint	Co-ordinates
Formalization and construction of an existing informal Taxi Rank with associated infrastructures within 500 meters of a wetland.	To formalize and construct an existing informal Taxi Rank with associated infrastructures within 500 meters of a wetland.	Portion 0 of the Remaining Extent of the Farm Soweto and The Remainder of the Farm Soweto 387-IQ.	291.9278 Hectares.	<b>Start:</b> S -26.242458 <sup>0</sup> E 27.839681 <sup>0</sup>  <b>End:</b> S -26.241994 <sup>0</sup> E 27.841470 <sup>0</sup>

Attached herewith is a copy of the General Authorisation for ease of reference and Registration Certificate will be issued later.

Yours sincerely



.....  
**DIRECTOR: INSTITUTIONAL MANAGEMENT**

**DATE:** 21 October 2020

- **Service letters from municipalities.**

**Water and Sewer:**

(City of Johannesburg – Johannesburg Water).



City of Johannesburg

Johannesburg Water SOC Ltd

17 Harrison Street  
Johannesburg

Johannesburg Water  
PO Box 61542  
Marshalltown  
2107

Tel +27(0) 11 688 1400  
Fax +27(0) 11 688 1528

[www.johannesburgwater.co.za](http://www.johannesburgwater.co.za)

Date: 1<sup>st</sup> August 2018

Our Reference: Soweto 387-IQ Erven 387-IQ

Your Ref.: 0901107C

**CSM CONSULTING**

Karee Building Unit C101

Tuinhof

265 West Avenue

Centurion

[admin@csmeng.co.za](mailto:admin@csmeng.co.za)

**ATTENTION: G. MKHABELA**

Dear Sir/Madam

**RE: SCHEME REPORT**

**SOWETO 387-IQ ERVEN 387-IQ (EMDENI TRANSPORT FACILITY)**

In reference to the report submitted 25<sup>th</sup> July 2018. Johannesburg Water acknowledges receipt of your scheme report. There is sufficient capacity on both water and sewer services to accommodate this development. Water and sewer connections where necessary can be applied for at City of Johannesburg People's Centre. Our Avalon Depot's new connection officer can assist with further information on new connections application. Their details are as follows:

Avalon Depot  
Calendala Road  
Klipspruit West  
011 947 1014

Should any additional information be required please do not hesitate to contact the writer.

Yours faithfully

(P.Cebani)

**For DEVELOPMENT CONTROL**

0116886943

[philani.cebani@jwater.co.za](mailto:philani.cebani@jwater.co.za)

Directors:

Ms Getty Simelane (Chairperson), Ms Busisiwe Shongwe (Financial Director), Ms Gugu Moloi, Adv John Mateya, Ms Khanyisa Mdutshane, Mr Maselaganye Matji, Mr Simphiwe Kondlo, Mr Brandon Furstenburg, Ms Azwiedziswi Tshivhunge, Mr Ryan Mudliar

Mr Graham Luden (Company Secretary),  
Johannesburg Water SOC Ltd  
Registration Number: 2000/029271/07

**Stormwater:**

(City of Johannesburg – Johannesburg Roads Agency).



a world class African city



City of Johannesburg  
Johannesburg Roads Agency

75 Helen Joseph Street  
Cnr. Harrison Street  
Johannesburg  
2001

P/Bag X70  
Braamfontein  
South Africa  
2017

Tel +27(0) 11 298 5000  
Fax +27(0) 11 298 5178  
[www.jra.org.za](http://www.jra.org.za)  
[www.joburg.org.za](http://www.joburg.org.za)

**Tel: (011) 298-5268**  
**Fax: (011) 298-5066**

**12/3/Z07-3**  
**W Sekati**

CSM Consulting Services (Pty) Ltd  
Karee Building Unit C101  
Tuinhof  
265 West Avenue  
Centurion  
0157

Date: 17 March 2021

Email: [gmkhabela@csmeng.co.za](mailto:gmkhabela@csmeng.co.za)

Attention: Ms. Gugulethu Mkhabela

Dear Madam,

**EMDENI/ZOLA PUBLIC TRANSPORT FACILITY, ZOLA EXTENSION 3: STORMWATER  
MANAGEMENT PLAN REVISION 4**

Your Stormwater Management Plan Revision 4 (SWMR) dated 10 December 2020 received by JRA: Development Control -Public on the 25<sup>th</sup> of February 2021, our telephone discussion on the 8<sup>th</sup> of March 2021 refers.

The following must be addressed before the acceptance of the revised stormwater management plan:

1. The town planning process (township establishment) must be finalized prior to the resubmission of the stormwater management plan.
2. On finalization of the town planning process, the revised SWMP should be submitted addressing the following:
  - The stormwater layout plan should clearly indicate the attenuation ponds (capacity, inlets and outlets, and how they discharge into the stream), contour lines, stormwater catchment areas, flow direction, pipe sizes, parking area, landscaping area, etc.
  - The stormwater layout plan should clearly indicate the attenuation pond/s and its catchment area.
  - The details (inlets, outlet structures, etc.) of the attenuation facility should be clearly reflected on the detail design drawings.

Chairman: Dr. A Mokoena

Executive Directors - Chief Executive Officer: S Monakedi, Chief Financial Officer: D Thindisa

Non-Executive Directors: L Mdluli, H Mtimkhulu, F Ntsandeni, L Ndllovu, N Mla, T Seemela, T Tshitangano, Y Ngxabazi, S Chiloane-Nwabueze, E Mtshali, S Ralegoma  
Company Secretary: P Majola

Registration No. 2000/028993/30



- The attenuation ponds (1, 2 & 3) capacity of 291m<sup>3</sup> reflected on your stormwater layout does not correlate with the pond volume of 338m<sup>3</sup> as indicated in the report. The sizing of the attenuation facility should be in accordance with the JRA stormwater policy.

Please note that the SDP can only be accepted by the JRA once the town planning process has been finalized and the revised stormwater management plan has been accepted.

Yours sincerely

A handwritten signature in black ink, appearing to be 'WS' with a stylized flourish.

**Senior Engineer: Development Control – Public**

WS