

VRYSTAAT LANDMETING

VRYSTAAT LANDMETING



FREE STATE LAND SURVEY

POSBUS 353
P.O. BOX
9300

TEL: (051) 4042843
FAX: (051) 4042829

VOERDER : FEEDER : BALKFONTEIN PUMPS - WINKELSPPOST					BESTAANDE KRAGLYN INLICHTING EXISTING POWERLINE INFORMATION		
PROJEK No.: PROJECT No.: BW408-REFURB					STRUKTUUR TIEPE : STRUCTURE TYPE :		
VERBRUIKER : CONSUMER : ESKOM					ADMIN DISTRIK : ADMIN DISTRICT : BOTHAVILLE		
GELEIER : CONDUCTOR :	FOX METER	MINK METER	HARE METER	TOTAL/TOTAAL METER	OPGEMEET : SURVEYED : N. NELSON	DATUM : DATE : 09/2013	
LENGTE : LENGTH :	12721.5		14615.5	27337	GETEKEN : DRAWN : J. ACKERMANN	DATUM : DATE : 09/2013	

MATERIAL LIST

DRAWING No.	DESCRIPTION	QTY
	FOX STRUCTURES	
DDT1804	3 PH TAKE-OFF-2,5M WOODEN X-ARM	5
DDT1849	EQUIPMENT LINKS CUT-OUTS 2.5m X-ARM S-POLE	5
DDT1860	16-50kVA TRF S-POLE	7
DDT1746	3 PH-DELTA/2,5M WOOD X-ARM-STRAIN-TERMINAL	7
DDT1806	3 PH TAKE-OFF-H-POLE (3,5M WOODEN X-ARM)	1
DDT1763	3 PH-H-POLE/3,5M WOOD X-ARM-STRAIN-ØDEG DEV	7
DDT1852	BY PASS LINKS - CUT/OUTS 3.5m X-ARM - H-POLE	4
DDT1866	16 - 50kVA TRF (OUT OF LINE)	1
DDT1870	3 PH-T-FRAME/2M STEEL X-ARM-INT-ØDEG DEV	82
DDT1873	3 PH-H-POLE/2 X 4,5M WOOD X-ARM-STRAIN-LARGE(61DEG-90DEG) DEV	2
DDT1764	3 PH-H-POLE/3,5M WOOD X-ARM-STRAIN-MED(1DEG-60DEG) DEV	2
	HARE STRUCTURES	
DDT1767	3 PH-H-POLE/2 X 3,5M WOOD X-ARM-STRAIN-ØDEG DEV	19
DDT1870	3 PH-T-FRAME/2M STEEL X-ARM-INT-ØDEG DEV	143
DDT1807	3 PH TAKE-OFF-H-POLE (2 X 3,5M WOODEN X-ARM)	1
DDT1768	3 PH-H-POLE/2 X 3,5M WOOD X-ARM-STRAIN-MED(1DEG-60DEG) DEV	14
DDT1805	3 PH TAKE-OFF-2x 2,5M WOODEN X-ARM	4
DDT1769	3 PH-H-POLE/2 X 3,5M WOOD X-ARM-STRAIN-TERMINAL	1
DDT1873	3 PH-H-POLE/2 X 4,5M WOOD X-ARM-STRAIN-LARGE(61DEG-90DEG) DEV	1

POLES	9m		11m	309	12m	27	13m	3	14m		15m		16m		18m		STAYS ANKERS	283	STRUTS STUTTE	8
-------	----	--	-----	-----	-----	----	-----	---	-----	--	-----	--	-----	--	-----	--	-----------------	-----	------------------	---

HEKKE - GATES D-FS-1 SHEET 2	TOTAAL - TOTAL	KRUISINGS - CROSSINGS	GPS FILE: BW-408REFURB
---------------------------------	----------------	-----------------------	------------------------

TIEPE KRUISING TYPE OF CROSSING	PAD / ROAD	TELKOM	SPOOR / RAILWAY	NASIONALE PAD NASIONAL ROAD	POWERLINE	TRANSFORMOR - TRANSFORMATOR			
AANTAL TOTAL						16kVA	25kVA	50kVA	100kVA

EIENAARSKEDULE/PROPERTY OWNER DETAIL

PLAASBESKRYWING - FARM DESCRIPTION	GERIGISTREERDE EIENAAR - REGISTERED OWNER	TELEFOON No. - TELEPHONE No.	VOORW.
	SEE WAYLEAVE SCHEDULE		

HIERMEE GESERTIFISEER DAT DIE KRAGLYN GEBOU IS VOLGENS DIE SPANPLAN, EN DAT PAAL NOMMERS ASOOK ENIGE TOERUSTING OP SPANPLAN AANGETOON IS	----- HANDTEKENING ----- DATUM
---	---