

**UKUHLONGOZWA KOKUBEKWA KOMKHUMBI OPHEHLA AMANDLA KAGESI NGOKUGUQULA
IGESI ECHWEBENI LASERICHARDS BAY KUMASPALA WASEKHAYA UMHLATHUZE, ESFUNDENI
SENKOSI UCETSHWAYO, EKWAZULU NATALI**

**ISIGABA SOMBKO WOMTHELELA KWEZEVELO (EIR) NGOKWEMIGOMO YOMTHETHONQUBO YE-EIA YONYAKA KA-2014
(NJENGOBA UCHITSHIYELWE)**

AbakwaTriplo4 Sustainable Solutions (Pty) Ltd benza inqubo yokuhlolwa kwezemvelo (EIA) edingekayo mayelana nesicelo **seKarpowership (Pty) Ltd** sokugunyazwa kwezeMvelo (ngokoMthetho Kazwelone Wokuphathwa Kwezemvelo, 1998) futhi bafaka isicelo seLayisensi Yokungcola Emkhathini (AEL) (ngokoMthetho Kazwelone Wokuphathwa Kwezemvelo: Umthetho Wekhwalithi Yomoya, 2004) **yeprojekthi ehlongozwayo yokubekwa komkhumbi ophehla amandla kagesi ngokuguqula igesi echwebeni laseRichards Bay**, kumaspala wasekhaya uMhlathuze, esifundeni seNkosi uCetshwayo, eKwaZulu Natali.

Isigaba Sokulinganisa, esiqale ekuqaleni kwaMfumfu enyakeni wezi-2020 siphothulwe ngokwamukelwa Kombiko Wokulinganisa, kufaka phakathi uhlelo Iwezicwaningo ze-EIA, nguMnyango Wezemvelo, Amahlathi kanye Nezokudoba (i-DEFF) ngomhlaka 6 kuMasingana wezi-2021. Ngakho-ke, isicelo manje sesisesigabeni se-EIR.

Imininingwane yeprojekthi: Iphrokthi ifaka phakathi ukwenziwa kukagesi ovela emikhunjini emibili entantayo eboshwelwe echwebeni laseRichards Bay ezomukela igesi yemvelo komunye umkhumbi wesithathu, obizwa nge-Floating Storage Regasification Unit (i-FSRU). Le mikhumbi emithathu kulindeleke ukuthi ihlale echwebeni iminyaka engama-20 okuyisikhathi esikalelw le phrokthi. Njalo emva kwezinsuku ezingama-20 kuya kwezingama-30 kuzofika umkhumbi obizwa nge-Liquified Natural Gas Carrier uzoletha igesi yemvelo ezobe isesimweni samanzi izoyithulula emkhunjini lo oyIFSRU. Iglesi yemvelo izokhishwa kusuka kumkhumbi iFSRU iya emkhunjini ephehla ugesi ngamapayipi egesi azobe engaphansi kolwandle. Le phrokthi inomthamo wokuklama wokuphehla ugesi ongama-540MW ngezinjini zegesi ezingama-27, injini iyodwa izodinga ukushisa okungapezulu kwe-10MW. AmaTurbine ama-3 ashisa injini akhipha ukushisa okuyi-15.45MW ngamunye. Ukusuka emkhunjini, ugesi uzokhishwa ngentambo kagesi eyi-132kV ngebanga elicishe libe ngama-3km, ukusuka eRichards Bay Port kuya kulayini wakwa-Eskom, endaweni yokuxhuma (edinga isiteshi esisha esishintshayo) eduze ne-Bayside Substation ekhona, engena kugridi kazwelonek.

INGXENYE YENQUBO YOKUBAMBA IQHAZA KOMPHAKATHI – ISIGABA SE-EIR

Ukuphawula ngombiko osewuhlaka lokuqala we-EIA:

Umbiko osewuhlaka lokuqala we-EIA (okubandakanya uHlelo Lokuphathwa Kwezemvelo (EMPr) nemibiko yochwepheshi) izotholakala kumaQembu Anenthisekelo Nathintekayo (ama-I & AP), kufaka phakathi iMinyango Yombuso kanye ne-DEFF ukuze baphawule ngezinsuku ezingama-30 esikhathini esiqala ngomhlaka **26 Nhlanjana kuye kumhlaka 31 Ndasa ku-2021** kumtapo wolwazi womphakathi waseRichards Bay, emahovisi eTriplo4 eBallito, kuwebhusaythi yaseTriplo4: www.triplo4.com nasenkundleni yelnthanethi yamaQembu Anenthisekelo Nathintekayo(ama-I & AP). **Uyacelwa ukuthi uthinte ihhovisi le-Triplo4 uma uhlangabezana nobunzima ekutholeni le mibiko.**

Imihlangano Yomphakathi Nababambe iqhaza:

Njengengxene yenqubo yokubamba iqhaza komphakathi, imihlangano izokwenziwa ngokuzimela, kusetshenziswa izinkundla zemihlangano eziku-inthanethi ukuvumela ukubamba iqhaza ngesikhathi sobhubhane Iwe-COVID-19. Kunikezwa amaseshini amabili ezikhathi zomhlangano - iseshini yasekuseni neseshini yakusihlwa. Imininingwane efanayo izonikezwa kuzo zombili izikhathi futhi ama-I & AP abhalisiwe azothola amaminithi awo womabili amaseshini. Imibuzo nomu ukuphawula kungathunyelwa ngaphambi kwemihlangano eku-inthanethi.

Imihlangano izoba ngoLwesine, **11 Ndasa 2021 ngo-10: 00 nango-18: 00.**

Izixhumanisi zokungena kule mihilangano eku-inthanethi zisonikezwa ama-I & AP abhalisiwe kusasele isonto wenziwe umhlangano.

Kuma-I & AP angakwazi ukubamba iqhaza kuzinkundla ezinjalo, sicela uxhumane nabakwaTriplo4 kusengaphambili ukuze kwenziwe olunye usizo noma amanye amalungiselelo okubamba iqhaza angenziwa.

Sicela uthumele konke ukuphawula kanye nezicelo zokubhaliswa njenge-I & AP (uma ingakabhaliswa) kanye / noma eminye imininingwane ku:

UNkk. Hantie Plomp

Triplo4 Sustainable Solutions

Douglas Crowe Drive, The Circle, Suite 5, Ballito

P.O. Box 6595, Zimbali, 4418

Tel | 032 946 3213

Fax | 032 946 0826

E-mail | ppprbay.triplo4@gmail.com

