

**ISAZISO SOKUFAKA ISICELO SOKUGUNYAZWA KWEZEMVELO KANYENELAYISENSI YOKUNGCOLA
EMKHATHINI**

**UKUHLONGOZWA KOKUBEKWA KOMKHUMBI OPHEHLA AMANDLA KAGESI ECHWEBENI LASERICHARDS
BAY KUMASIPALA WASEKHAYA UMHLATHUZE, ESIFUNDENI SENKOSI UCETSHWAYO, KWAZULU NATAL**

Ukukhishwa kwesaziso ngokwemigomo yoMthethonqubo wama-41 weMithethonqubo Yokuhlolwa Kokuthinteka Kwezemvelo (i-EIA), yonyaka wezi-2014 eyashicilelwa kuSaziso sikaHulumeni esinguNombolo R982 (njengoba uchitshiyelwe) ngaphansi koMthetho Kazwelonke Wokuphathwa Kwezemvelo ka-107 (1998) (NEMA) womfakisicelo, i-Karpowerhip SA (Pty) Ltd ihlose ukufaka isicelo kuMnyango Wezemvelo, Amahlathi kanye Nezokudoba (i-DEFF) sokugunyazwa kwezemvelo

Ngaphezu kwalokho, ukukhishwa kwesaziso ngokoMthetho Kazwelonke Wokuphathwa Kwezemvelo: Umthetho Womoya Oyikhwalihi owunombolo 39 wezi-2004 (NEMAQA) wokuthi iKarpowerhip SA (Pty) Ltd ifaka isicelo ngasikhathi sine ku-DEFF ukuthola Ilayisense Yokungcola Emkhathini (AEL).

Izinqubo zokubekwa komkhawulo nezomthelela kwezemvelo ziyasetshenziswa kulezi zinhlelo.

Imininingwane yeprojekthi: Iprojekthi ifaka phakathi ukwenziwa kukagesi ovela kumkhumbi ontantayo eboshwelwe echwebeni laseRichards Bay. Lokhu kufaka phakathi ukukhululwa kwemikhumbi emithathu ngesikhathi sokusebenza kweprojekthi, i-Floating Storage Regasification Unit (i-FSRU) kanye namikhumbi kagesi emibili. Inkampani ethwala Igesi yemvelo (i-Liquefied Natural Gas Carrier (LNGC) izonikezela nge-LNG ku-FSRU ngesikhathi esifushane (izinsuku ezi-1-2). Igesi yemvelo izokhishwa kusuka ku-FSRU iye kumkhumbi ophehla amandla kagesi ngepayipi legesi. Umthamo ohlongozwayo wokuklama weRichards Bay Powerhip ungama-554MW, aqukethe injini zamagesi ezingama-27, injini ngayinye ikhipha umthamo olinganiselwa e-18.32 MW. Ukusuka emkhunjini, ugesi uzokhishwa ngentambo kagesi engu-132kV ngebanga elicishe libe ngu-3km, ukusuka echwebeni laseRichards Bay kuya esiteshini esingaphansi kweBayside..

Indawo: Iprojekthi ehlongozwayo itholakala echwebeni laseRichards Bay. Uphiko Lokugcina Isitoreji Esintantayo (FSRU) kanye nePowerhips kuzobanjelwa ngaphakathi echwebeni laseRichards Bay. Amandla avela emkhunjini azokhishwa ngentambo yokuhambisa ngebanga elicishe libe ngu-3km ukuya esiteshini esincane saseBayside esizodinga ukwakhiwa ngaphakathi noma ngaphakathi kwamamitha angama-32 omsele wamanzi nokugcwaliswa / ukususwa kwanoma iyiphi impahla engamamitha ayi-cubic ayi-10 ukusuka emgodini wamanzi kanye nempahla engama-cubic metres ayi-5 esuka emfuleni..

INQUBO YOKUBAMBA IQHAZA KOMPHAKATHI

Bhalisa nienge-I & AP: Amaqembu Anentshisekelo Nathintekayo (ama-I & APs) ayamenywa ukuthi abhalise ngokuthumela igama lawo, imininingwane yokuxhumana kanye nentshisekelo kuprojekthi esebenzisa imininingwane yokuxhumana enikezwe ngezansi. Sicela ubhalise ngokushesha okukhulu ukuze ugcine unolwazi ngalo lonke uhlelo lokufaka isicelo, kufaka phakathi isaziso sanoma yimiphi imihlangano ebanjwayo kanye nezixhumanisi zamapulatifomu aku-inthanethi.

Phawula ngemibiko: Njengengxenywe yenqubo yokubamba iqhaza komphakathi, uyamenywa ukuthi ubuyekeze futhi ubeke amazwana kuMbiko Wokuhlela Okusalungiswa ozotholakala isikhathi esiyizinsuku ezingama-30 kusukela mhla ziyi-6 kuMfumfu kuya kumhlaka-4 kuLwezi 2020 enkundleni ye-inthanethi yakwaTriplo4 Sustainable Solutions (Pty) Ltd: www.triplo4.com nasenkundleni ye-Intanethi yalaba ababhalisiwe njengama-I & AP.

Ngokuya koMbiko Wokuhlela wamukelwa yi-DEFF, Umbiko Wokuhlela Komthelela Wemvelo uzokwenziwa utholakale ukuze uphawule ngokuhamba kwesikhathi ozokwaziswa.

Sicela uthumele yonke imibono nezicelo zokubhaliswa kanye / noma eminye imininingwane, mayelana nokubhekwa kweMvelo nesicelo seAEL, ku:

UNkk. Hantie Plomp
Triplo4 Sustainable Solutions
P.O. Box 6595, Zimbali, 4418
Ucingo | 032 946 3213
IFekisi | 032 946 0826
Imeyili | ppprbay.triplo4@gmail.com

Usuku Lokukhangisa: 23 kuMandulo 2020

