



REFERENCE DRAWINGS		
ITEM	DESCRIPTION	DWG NO
CONDUCTOR / INSULATOR ATTACHMENTS		
1	STRAINS -HELICAL DEAD END -PISTOL GRIPS	D-DT-0250 D-DT-0251
INSULATOR / STRUCTURE ATTACHMENTS		
2	STRAINS -THREADED ROD	D-DT-0376
X-ARM STRUCTURE ATTACHMENTS		
3	STRAINS -2x3500 WOOD X-ARM/POLE	D-DT-0318
BONDING AND EARTHING		
	INSULATION CO-ORDINATION	D-DT-0310
STAYS		
4	STAY ATTACHMENTS STAY ASSEMBLY	D-DT-0313 D-DT-0341
PHASING		
	PHASE CONFIGURATION	D-DT-0311

	MIN. POLE DIAMETER			
CONDUCTOR	9m	10m	11m	12m
0 DEG. DEV.	140	140	160	160
SQUIRREL	140	140	160	160
FOX	140	140	160	160
MINK	140	160	160	160
HARE	160	180	180	180

3	RETICULATION REMOVED FROM TITLE BLOCK	N.M.	P.A.T.	01.10.09		
2	REF. TO STAY ASSY. ADDED & REF. No'S AND MIN. POLE DIA'S CHANGED	PBM	B. HILL	08.12.05		
REV	REVISION DESCRIPTION	BY	CHKD	AUTH	DATE	PROJECT NO.

	ESKOM MV THREE PHASE H-POLE / 2 x 3500 WOODEN CROSSARM STRAIN - TERMINAL					
	AUTH: B. BRANFIELD					
	DATE: 11/01/1999					
	CHKD: B. BRANFIELD					
DATE: 11/01/1999				SET	SHEET	REVISION
DRAWN: IAN B. P.A. VERMAAK		D-DT-1769		1	1	3
DATE: 23/06/1998						