

GS.NDABA - 073 524 5825

WESLEY NB111

30 07 00.349 S, 29 51 40.148 E.
30 07 10.629 S, 29 51 33.620 E.

5221 ES

PTN 13 OF 5464 ES

UR418
16kVA

23559 ES

NM.MHLONGO
UBR418H2
20A PREPAID SUPPLY
34m 10mm AIRDAC

GS.NDABA
UBR418H3
20A PREPAID SUPPLY
40m 10mm AIRDAC

HT.MANCI
UBR418H4
20A PREPAID SUPPLY
15m 10mm AIRDAC

E-1744.1848.
T586L24
ADD

BP.HLENGWA
UBR418H1
20A PREPAID SUPPLY
18m 10mm AIRDAC

E-1740B.1814

23712 ES

23682 ES

S-WN : 529C/3029BBN
CONDUCTOR : 2C ABC,10mm AIRDAC
LINE LENGTH : 0.631km,0.106km
SHEET LENGTH : 737m
SHEET 2 / 2
SCALE 1 : 5000

SURVEYOR : LUCAS



DRAWN GETEKEN	VS	CHKD NAGES	LUCAS	AUTH MAS	REV	DATE DATUM	22/04/2011
------------------	----	---------------	-------	-------------	-----	---------------	------------



WESLEY 22KV
SUPPLY TO : GS.NDABA
AND OTHERS - UR418H1-H4

D : LN/005
K2 : I66225344B
GPS : I66225344B

DRG.TEK REGISTR		
--------------------	--	--