

DO NOT HAVE
THIS APPROVAL
ON ITS FIRST
DATE.

SHEET

COPY

CITY OF DURBAN

304 12 01

PLAN No.

APPROVED: Ms. J SUBBAN
EXECUTIVE DIRECTOR, DEVELOPMENT
& PLANNING UNIT

DATE: 22 JAN 2002

PER

ELECTRICITY SERVICES

Any person undertaking erection of a structure/sign
in accordance with this plan is to ensure that:

- (1) The electrical installation complies with the Code of
Practices for the wiring of Premises SABS 0142-1997, as
amended, and the Occupational Health and Safety
Act 85/1993

(2) Certificate of Compliance and Application for
Permission to Connect is lodged with DME prior to
electrical connection to the supply source

(3) Adequate earthing to the satisfaction of the Director;
if not, DME is provided.

ELECTRICITY SERVICES

Person undertaking building operations in respect of
structure/sign is required to ascertain from the Executive
Director before commencing.

(1) Location of any electrical services and services in
vicinity of the proposed works.

(2) Requirements regarding Substation, Meter room,
etc.

"It should be noted that this plan
has been approved on the basis
of information thereon."

FRONTAGE LEVELS ARE

- (1) TO CONFORM TO THE BACK OF THE
CONSTRUCTED SIDEWALK, OR
- (2) TO BE CALCULATED BY THE USE OF THE
FOLLOWING FORMULA $FL = E + 0,150M \cdot D$

(WHERE FL=FRONTAGE LEVEL, E=LEVEL OF EDGE
OF HARDENED ROAD AND D=DISTANCE IN METRES
BETWEEN EDGE OF ROAD HARDENING AND ROAD
RESERVE BOUNDARY)

TO DETERMINE THE CORRECT FRONTAGE LEVEL