

APPENDIX E2: BOREHOLE TEST CERTIFICATE

Goodspeed & Sons Water Boring t/a Randburg Water Boring

No 86 Modderfontein Rd, President Park, Midrand

EMAIL: info@rvbboreholepumps.co.za

REGISTRATION NO:2006/136643/23

CELL: 0829033751/0828946047

BOREHOLE TEST CERTIFICATE

CLIENT NAME: Door Of Hope Childrens' Mission

SITE: Door of Hope Village

DATE OF TEST: 10/10/2018

BOREHOLE DEPTH: 50 METERS

STATIC WATER LEVEL: 27 METERS

YIELD: 10 500 LITRES/HR

The yield of the borehole is a constant flow of 10500 LTR/HR

The 24 hour yield is 252 000 liters

DURATION: 4 HRS

TESTED BY: BRENDON GOODSPEED