

Buro Tech Consulting Engineers CC

141 Main Street, Heatherdale, Akasia, 0182 PO Box 59887, Karenpark, 0118

Tel: 00 27 (0)12) 542 1010

Fax: 086 516 4024

E-mail: burotech@burotech.co.za Website: www.burotech.co.za

To:Nkanivo Development ConsultantsFrom:Nico van WykTel No:083 277 7347Cell No:082 600 8328

For Att: Mr. Nyiko Baloyi Email nicovw@burotech.co.za

Email: nyiko@nkanivo.co.za Page: 1 of 17

Date: 11 Nov 2022 **Ref:** PL06-X2/DSN

RE: PROPOSED TOWNSHIP DEVELOPMENT - GREATER SEVILLE EXTENSION 2,

SITUATED ON REMAINDER OF PORTION 1 AND 2 OF THE FARM SEVILLE 224

KU

ELECTRICAL SERVICES – BASIC OUTLINE SERVICES REPORT – Version 2

Dear Mr Baloyi,

Enclosed please find for your information and attention the <u>basic outline services report</u> for the electrical services as requested.

Update Notes

Version

01: 24 August 2022 Original Issue

02: 11 November 2022 Report updated to latest Layout, reserved township names & land

description.

Kindly contact us should any additional information be required.

Yours Faithfully

Míco van Wyk (Pr. Eng)

Cc: Nil

Enclosed: Report Version 2





ELECTRICAL SERVICES

BASIC OUTLINE SERVICES REPORT

PROPOSED TOWNSHIP DEVELOPMENT GREATER SEVILLE X2

SITUATED ON REMAINDER OF PORTION 1 AND 2 OF THE FARM SEVILLE 224 KU





PREPARED BY:

BURO TECH CONSULTING ENGINEERS CC PO Box 59887 KARENPARK 0118

Tel: 012 542 1010

Email: burotech@burotech.co.za

PREPARED FOR:

Nkanivo Development Consultants Unit 79, Block 5, Lombardy 66 Graham Road PRETORIA 0084

Tel: 012 807 7445

Email: nyiko@nkanivo.co.za

DATE: 11 Nov 2022 PROJECT: PL06-X2

Version 2

Contents

1.	INTRODUCTION	_ 2
2.	BRIEF ON EXISTING NETWORKS	_ 3
3.	ESTIMATED ELECTRICITY DEMAND	_ 5
4.	AVAILABLE CAPACITY	_ 5
5.	CONCLUSION	_ 6
ΔΝ	NEXLIRES:	6

PROPOSED TOWNSHIP DEVELOPMENT – GREATER SEVILLE EXTENSION 2, SITUATED ON REMAINDER OF PORTION 1 AND 2 OF THE FARM SEVILLE 224 KU ELECTRICAL SERVICES – BASIC OUTLINE SERVICES REPORT

Date: 11 Nov 2022

Version 2

1. Introduction

Buro Tech Consulting Engineers was appointed on 28 July 2022 as specialist electrical engineers by Mr. Samuel Chauke, managing director at Nkanivo Development Consultants for the proposed development of Greater Seville X2, situated on Remainder of Portion 1 and 2 of the Farm Seville 224 KU.

This report is based on the following information received from:

- Feedback form Eskom dated 08 & 11 August 2022
- Nkanivo Development Consultant on 15 August 2022 with updates on 07 November 2022
- Site visit on 23 August 2022

The locality of the site is indicated below.




Image 1: Locality Map - Greater Seville Extension 2

2. Brief on Existing Networks

Eskom is the supply authority in the area and have electrical infrastructure servicing adjacent townships in the area.

No electrical infrastructure is currently present on the project site.




Images 2: Overview of the project site

The area is supplied from the Acornhoek 275/132/22kV MTS Substation via the Acornhoek/Tintswalo 22kV overhead line (shown in red in the image further below).

Refer to images below:



Images 3: The Acornhoek 275/132/22kV MTS Substation



Images 4: Overview of the Acornhoek/Tintswalo 22kV overhead line

Refer to images below for typical medium voltage equipment on the existing Acornhoek/Tintswalo 22kV overhead line in areas adjacent to the project site.



Images 4: The Site, Typical Overhead Medium Voltage (22kV) Lines

3. Estimated Electricity Demand

The electrical demand for Greater Seville Extension 2 is calculated to be:

Erf#	AREA OF ERF Hectare	PROPOSED ZONING	LAND USE COMPONENTS	Units	FAR	DEVELOPABLE FLOOR AREA (m²)	kVA/unit or VA/m²	Unit	Total Load (kVA)
483	28.3400 Ha	Res 1	Dwellign Units(s)	483			2.00	kVA[ADMD]	966.00 kVA
3	0.2000 Ha	Bus 1	Shops/Retail		0.50	1 000.00 m²	80.00	VA/m²	80.00 kVA
3	0.6100 Ha	Institutional	Place of Worship				13.80	kVA	41.40 kVA
3	4.3000 Ha	Educational	Creche			_	13.80	kVA	41.40 kVA
3	2.0600 Ha	Municipal	Munic Purposes		0.50	10 300.00 m²	80.00	VA/m²	824.00 kV
3	1.4900 Ha	Public Open Space	Open Space			_	13.80	kVA	41.40 kV
	15.0200 Ha	Roads	Roads						
SUB-TOTAL									1 994.20 kV
Diversity Factor									75%
SUB-TOTAL									1 495.65 kVA

TOTAL CALCULATED DEMAND

1.50 MVA

4. Available capacity

Eskom indicated that the Acornhoek MTS Substation have an installed capacity of 2x 40MVA and is currently loaded to 93.9% of firm capacity (thus 37.56MVA).

Eskom indicated that the Acornhoek/Tintswalo 22kV overhead feeder have no spare capacity available.

Eskom indicated that the new Tsakani substation is currently being constructed to:

- De-load the existing Acornhoek/Tintswalo 22kV feeder, and
- unlock additional capacity to the area.



Images 5: Locality of the Project Site with relation to the Eskom Substations

The new Tsakani substation will be located towards Hluvukani have an installed capacity of 1x 20MVA and is scheduled for completion by the end of the 2023/24 financial year.

Refer to Annexure 01 for Eskom correspondence dated 08 & 11 August 2022.

5. Conclusion

The final maximum demand to the new development is calculated to be 1.50 MVA.

The new 1x 20MVA Tsakani substation scheduled for completion in the 2023/24 financial year is intended to unlock additional capacity to the region.

Eskom will require a formal application process to be followed for official feedback and to reserve capacity in this regard.

Annexures:

Annexure 01: Township Layout Plan (Updated) (1 Page)

Annexure 02: Eskom Feedback dated 08 & 11 August 2022 (4 Pages)

Annexure 03: Overview of the Eskom 22kV overhead distribution feeders (1 Page)


---0000000---

ANNEXURE 01

Township Layout Plan (1 Page)

GREATER SEVILLE EXTENSION 2 TOWNSHIP LAYOUT PLAN

SITUATED ON A PORTION OF THE REMAINDER OF PORTION 1 AND 2 OF THE FARM SEVILLE 224 KU



SOIL CLASSIFICATION					GEOTECHNICAL INFORMATION	LAND INFORMATION	SCALE
SITE CLASS	DESCRIPTION	DEVELOPMENT POTENTIAL	CONSTRUCTION TYPE	FOUNDATION RECOMMENDATION		FLOODLINE CERTIFICATE	1:1300 (A1 Format)
							1:2 600 (A2 Format) 1:5 200 (A3 Format) 1:10 400 (A4 Format)
					SIGNED:	SIGNED:	1:10 400 (A4 Format) =

LOCALITY MAP



LEGEND

ZONING	LAND USES	NO. OF ERF	AREA (HA)	AREA (%)	NOTATION
RESIDENTIAL 1	DWELLING UNIT/S	483	28.34	54.03	
BUSINESS 1	SHOPS/RETAIL	3	0.20	0.38	
INSTITUTIONAL	PLACE OF WORSHIP	3	0.61	0.16	
EDUCATIONAL	SECONDARY SCHOOL/CRECHE	3	4.30	8.19	
MUNICIPAL/GOVERNMENT	MUNICIPAL PURPOSES	3	2.06	3.93	
PUBLIC OPEN SPACE	OPEN SPACE	3	1.49	2.84	
ROAD PURPOSES	PROPOSED ROADS		15.45	29.47	
TOTAL DEVELO	PABLE AREA	498	52.45	100%	

NOTES:

Represents Proposed Township Boun
 Road Reserves: 12m, 15m, & 35m

SURVEY NOTES:

CONTOUR INTERVALS 1 M IN ACCORDANCE TO REG.ORDINANCESURVEYOR GENERAL SYSTEM WGS 84

SIGNATURE

CLIENT:

CONSULTANTS



NKANIVO DEVELOPMEN	T CONSULTANTS	SAMUEL CHAUKE	
DESIGNED: CHECKED: DRAWING No: DATE:	NYIKO BALOYI Pr.Pin A/3125/2022 SAMUEL CHAUKE Pr.Pin A/3130/2022 202206-SEV/EXT2/REV1 04/11/2022	THESE DRAWINGS: (A) ENJOY COPYRIGHT PROTECTION AND IN NKANIVO DEVELOPMENT CONSULTANI UNLESS OTHERWISE AGREED IN WRITING (B) MAY NOT BE REPRODUCED OR TRANS OR BY ANY MEANS WHATSOEVER TO ANY THE WRITTEN PERMISSION OF THE COPYR	MITTED IN ANY FORM PERSON WITHOUT

COMPILED BY:



TELL: 012 807 7445 eMail: info@nkanivo.co.za Nkanivo House Unit 79, Block 5, Lombardy Business Park 66 Graham Road Pretoria 0084

ANNEXURE 02

Eskom Feedback (4 Pages)

Ralph Gordon

From: Cyril Thete <TheteC@eskom.co.za>

Sent: 11 August 2022 09:12

To: Ralph Gordon

Subject: RE: Seville - Overview of Electrical networks

Sensitivity: Confidential

Good day Ralph,

The installed capacity will be 1x20MVA

The substation should be completed by the end of 2023/24 Financial Year.

Regards

Cyril Thete

From: Ralph Gordon <ralphg@burotech.co.za>

Sent: Monday, 08 August 2022 16:01 **To:** Cyril Thete <TheteC@eskom.co.za>

Subject: [CAUTION:EXTERNAL EMAIL] - RE: Seville - Overview of Electrical networks

Sensitivity: Confidential

Good day Cyril,

Thank you for your fast response, much appreciated!

Regarding the Tsakani Substation:

What will be the installed capacity?

When is the substation expected to be commissioned?

Best Regards,



Ralph Gordon

Buro Tech Consulting Engineers

Tel: +27 (012) 542 1010

Cell: 082 600 2537

Ralphg@burotech.co.za

BURO TECH www.burotech.co.za

From: Cyril Thete [mailto:TheteC@eskom.co.za]

Sent: 08 August 2022 14:21

To: Ralph Gordon < <u>ralphg@burotech.co.za</u>>

Subject: RE: Seville - Overview of Electrical networks


Sensitivity: Confidential

Good day Ralph

Below is the information I managed to gather as per your request.

- Line name Acornhoek/Tintswalo 22kV Overhead Line
- Line code AT

- Operating voltage 22kV
- Installed capacity (Not available Please see the next point)
- Spare capacity The feeder is currently overloading.
- Substation Name & Voltage Levels Acornhoek 275/132/22kV MTS Substation
- Substation Installed Capacity 2x40MVA
- Substation spare capacity The substation is currently loaded at 37.56MVA
- We have **Tsakani Substation** that is under construction at the moment and it is In Hluvukani, about 10km from Seville, this substation is going to solve the capacity constraints in that area including de-loading **AT feeder** and I am not aware of any upgrades planned at Acornhoek MTS (if that is what you are asking).
- I have attached a snapshot of the AT feeder for you. AT Feeder is highlighted In red and in the attachment I have also indicated where Seville Project area is and that will show you how far is it from the feeder.



Regards Cyril Thete

From: Ralph Gordon < ralphg@burotech.co.za >

Sent: Monday, 08 August 2022 11:09

To: Cyril Thete < TheteC@eskom.co.za>

Subject: [CAUTION:EXTERNAL EMAIL] - Seville - Overview of Electrical networks

Sensitivity: Confidential

Good morning Cyril,

I request your assistance with the following:

Introduction

Buro Tech has been appointed to submit a report giving an overview of the electrical services in the vicinity of the project, capacity availability & an overview of the Eskom masterplan for upgrades in the area to unlock capacity (if available).

Background


The area is earmarked for the development of residential erven with complimentary business, educational & municipal facilities.

The demand will be calculated once the proposed rights are available.

Locality

The proposed development is located at the following coordinates: 24°39'34.24"S 31°24'33.81"E

The Thulamahashe 132kV substation is located ±22km to the South-West of the proposed development.



Information requested

We request Eskom input in terms of the following:

Overview of the feeder line that will be supplying this development,

- Line name,
- line code,
- operating voltage,
- installed capacity,
- spare capacity (if any)
- A drawing indicating the line route if available.

We do not require feedback up to the detail of a planning proposal with network voltage studies, thermal capacity studies, fault levels, etc.

Overview of the distribution substation supplying this area,

- Substation Name & Voltage Levels (example: Thulamahashe 132/11kV substation)
- Substation Installed Capacity (example: 2x10MVA)
- Substation spare capacity (if any?), Perhaps the substation is loaded over firm capacity already? (please advise)
- Any substation upgrades envisaged in term of the Eskom masterplan for the area? (if any)

I acknowledge for more detailed studies & cost estimates the formal application process need to be followed, and will initiate the applications with Eskom, once the project reach this stage.

I look forward to your assistance in this regard. Many thanks.

Best Regards,

BURO TECH

Ralph Gordon
Buro Tech Consulting Engineers

Tel: +27 (012) 542 1010 Cell: 082 600 2537

BURO TECH www.burotech.co.za

NB: This Email and its contents are subject to the Eskom Holdings SOC Ltd EMAIL LEGAL NOTICE which can be viewed at http://www.eskom.co.za/Pages/Email_Legal_Spam_Disclaimer.aspx
NB: This Email and its contents are subject to the Eskom Holdings SOC Ltd EMAIL LEGAL NOTICE which can be viewed at http://www.eskom.co.za/Pages/Email_Legal_Spam_Disclaimer.aspx

ANNEXURE 03

OVERVIEW:
Eskom Acornhoek/Tintswalo 22kV overhead feeder
(1 Page)

