

Waterproof membrane to exterior walls

Waterproof membrane to exterior walls Min 1m high handrail to comply with

GENERAL NOTES: (Where Appicable)

- All dimensions to be checked before work con notified immediately of any discrepancies, error
- Only figured dimensions to be taken: drawings
- dimensions in mm's unless otherwise stated. All levels to be checked on site before any wo
- All reinforced concrete work to be strictly in acc engineers detail and specification.
- Damproof course to comply with S.A.N.S. 10-4 All walls to be reinforced with two courses brick
- Workmanship is to be of the highest standard The contractor is to locate and identify any / all
- to protect these from damage whilst on site thr
- The contractor is responsible for the correct se 9. particularly boundaries, building lines servitude 10. All work to be executed in strict accordance to
- LOCAL AUTHORITY BY-LAWS. All materials to be used in strict accordance to 11.
- 12. Any discrepancies conflicting with drawings pro attention of the consultants before proceeding

NOTE:

DRAINAGE NOTES:

- 1. Any damaged fittings to be replaced. 2. All gully surrounds and manhole covers to be 75mm
- Sewer connection to be exposed before commencin 4. I.e's to all bends and junctions.
- 5. All sewer pipes under buildings to be upvc ribbed pip 6. All WC's to have a dual flush function.

ROOF:

CEILING:

FOUNDATIONS:

REINFORCED CONCRETE STAIRCASES:

GLAZING:

PVC gutter & downpipe WALLS & LINTELS:

roof sheeting

Plaster & paint to match230mm externals common brick walls plastered and pa with SANS 10400-XA 4.4.3.2 (a) R-Value of 0.49 Lintels to comply with SANS 10400 part K - To Engine

FENESTRATION:

Therefore fenestration complies with SANS 10400 PAF SANS 10400 PART "O" 4.2.1.1.3 (a)

ENERGY DEMAND & CONSUMPTION:

HOT WATER SUPPLY: SANS 10252

MECHANICAL VENTILATION:

Air to internal toilets to be extracted to external at the

SCHEDULE OF AREA

GENERAL NOTES: (Where A	opicable)						
1. All dimensions to be checked before work commences. Architect to be							
2. Only figured dimension	notified immediately of any discrepancies, errors, omissions, etc. Only figured dimensions to be taken: drawings are not to be scaled. All dimensions in mm's unless otherwise stated.						
4. All reinforced concrete	All levels to be checked on site before any work commences. All reinforced concrete work to be strictly in accordance with structural engineers detail and specification.						
 Damproof course to co All walls to be reinforce 	mply with S.A.N.S. 10-400 of with two courses brickfor	ce at cill and wall plate levels.					
8. The contractor is to loc	of the highest standard thro ate and identify any / all exi	sting services and					
9. The contractor is respo	amage whilst on site throug onsible for the correct setting , building lines servitude's, e	g out of all works,					
10. All work to be executed LOCAL AUTHORITY E	d in strict accordance to S.A BY-LAWS.	A.N.S. 10-400 and					
12. Any discrepancies conf	d in strict accordance to ma flicting with drawings provid ants before proceeding with	ed are to be brought to the					
NOTE:							
 All STRUCTURAL, CIVIL and ELECTRICAL work to professional Engineers detail. All STRUCTURAL, CIVIL & ELECTRICAL ENGINEERS details to take preference over structural, civil & electrical details indicated. 			I.				
DRAINAGE NOTES: 1. Any damaged fittings to be re 2. All gully surrounds and manh 3. Sewer connection to be expo 4. I.e's to all bends and junction 5. All sewer pipes under building 6. All WC's to have a dual flush	ole covers to be 75mm abo osed before commencing w ns. gs to be upvc ribbed pipes.	ork.					
ROOF:							
 <i>Ex. Marley Mornach</i> concrete tileson 38x38 timber battens @ max 320mm centres on engineered trusses resting on on 114mmx38mm wall plates & tiled into min. 3 courses of brickwork using galvanised hoop straps. Trusses to be designed & certified by professional engineer. All roofed areas to receive THERMAL INSULATION - 110mm THICK ISOTHERM INSULATION, DENSITY 11.5kg/m³ R VALUE 2.79 to be Tiasa Approved - Roof pitch 17.5° All to SANS 10400 Part L. 25 x 10mm fascia board. Ancillary Unit: Long span zinc aluminium roof sheeting @ 17.5° on 76x38 purlins attached to engineered trusses. Roof by specialist. Proposed awnings: Long span zinc aluminium roof sheeting @ 4° on GMS box beams attached to 100x100 GMS posts. Roof and structure by specialist. Proposed Lapa: Thatch roof and structure by specialist. 							
CEILING: Rhinoboard ceiling on 38 x 38m plastered and painted white. Co		centres. Ceilings to be flush					
RAINWATER GOODS: SANS 10400 PART "R" 4.3 Ex. Gutters - 150 x 115mm aluminium. Ex. Rainwater downpipes - 100 x 100mm aluminium. All new Gutters and RWDP's to match existing.							
FOUNDATIONS: All foundations are existing. stri	ctly by engineer's detail and	1 design					
SURFACE BED: Concrete surface bed laid on approved dpm on brc mesh on well compacted & poisoned fill to engineer's detail.							
REINFORCED CONCRETE STAIRCASES: All reinforced concrete staircases to engineer'd detail. Treads and risers as per indicated on Achitect's drawings. Minimum head height of 2.1m to be maintained througthout stair							
flight. BALUSTRADING: SANS 1040 All balastrading, change of leve BALUSTRADE SPACING NOT 10400 PART D	and ramps to comply with						
GLAZING:							
All glazing to comply with SANS 10400 Part N. All safety glazing is to be permanently marked as per SANS 10400 part N - 4.4.1 All glazing within 1800mm of any shower or bath is to be TSG All glazing shower doors are to be 6mm TSG All windows extending below 500mm above finished floor level and glazed doors to be min. 4mm thick toughened safety glass to comply with sans 10400 part n, table 1.			nin.				
e WALLS & LINTELS: 2/230mm externals common brick walls plastered and painted both sides - In compliance with SANS 10400-XA 4.4.3.2 (a) R-Value of 0.49 Lintels to comply with SANS 10400 part K - To Engineers. Detail				Rev Date		scription	By
SANS 10400-XA & SANS 204 CALCS: Climate Zone 5 - Sub-tropical Coastal Oupancy Classification H4					© 2020, HD Proj	ROJEC	TC
FENESTRATION: To comply with SANS 10400 part "XA" Max permissible fenestration not requiring rational design is 15% The proposed additions and alterations do not exceed that of the allowed.				Contact: 071 495 00	PROFESSIONAL	ARCHITECTURAL S	ERVICES
Therefore fenestration complies	s with SANS 10400 PART "			sacap registration			
SANS 10400 PART "O" 4.2.1.1 ENERGY DEMAND & CONSU Maximum Permissible Energy of Maximum Permissible Energy of	MPTION: demand (W)	5W/m² 5kWh/m²		Clayton Human	• Pr Snr Arc	h Tech • PSATS	34028776
HOT WATER SUPPLY: SANS 10252 Insulation required Min. R-Value 1.00 for internal O Hot water pipe <80mm Glasswool Insulation on all external Hot water pipes. 50% 50% alternative means of heating: Gas geyser instillation by specialist				signatures	Ĕ	Harm.	owner
MECHANICAL VENTILATION: Fresh air supply of 17,5lt per sec/person with maximum air velocity of 0,5m/second to be provided to guest wc on first, second and third storey.			e	owner:		A December 1	author
Air to internal toilets to be extracted to external at the rate of 20lt sec/fitment.			Mr. G. A. Brown & Mrs. S. A. Brown				
NOTE: artificial ventilation and fresh air supply to mechanical engineers detail and specification				PROPOSED) ADDITIONS	8 & ALTERATIO D AVENUE, BL	
	SCHEDULE OF AREAS: Area of site: 1377sqm						1/Revit/4
	Permissable Coverage:	688.5sqm (50%)		rates number:			
	Existing Coverage: 260.1sqm Proposed Coverage: 172.1sqm -Ancillary unit: 49.2sqm -Awning 1: 33.6sqm -Awning 2: 57.5sqm			drawing title:	10		Proiects\58
				ELEVATION	12		
	-Awning 3: Lapa & Awning 4: Total Coverage:	8.0sqm 23.8sqm 432.2sqm		scale:		date:	M 2002
	Permissable F.A.R:	n/a		1:100		^{date:} 25/11/2021	Kvle\Documents
	Existing F.A.R: Proposed F.A.R: -Main dwelling: 6	183.9sqm 98.6sqm 0.5sqm		design: CH	drawn: KDL	checked: CH	
	-Ancillary unit: 3 Total F.A.R:			drawing number: 202	1-0927-102		revision:
					, 102		C