

ANNEXURE J1

DEPARTMENT OF ELECTRICITY APPROVAL LETTER



TRADING SERVICES

Electricity Unit

1 Jelf Taylor Crescent
Durban, 4001

PO Box 147, Durban, 4000

Tel: 031 311 1111

Fax: 031 311 9010

www.durban.gov.za

Our Ref : 27/2/1/1/18/VB/am – Doc. No. 4575
Your Ref: DL 4400634
Enquiries to: Mr V. Buddan Telephone: 031 311 9055

Architecture Department
eThekweni Municipality
166 K.E. Masinga Road
Durban

2021-10-05

Dear Sir/ Madam

234 Dr PIXLEY KASEME ST – DURBAN CBD: CITY HALL – DL 4400634

Substation plans for the above premises have been approved subject to the modifications shown in red being carried out.

Enclosed is a copy of your plan depicting the necessary alterations and a check list which is to be completed by yourself and submitted to eThekweni Electricity (TE), when requesting TE to inspect the completed substation and meter room. An engineer's certificate for all structural work must also accompany the checklist.

Upon completion of the substation and meter room, my Central Planning Section must be contacted to approve the above. Please note that the substation and meter accommodation must be inspected and approved, and all costs relating to this application must be paid, at least **12 weeks** prior to the required connection date.

For an inspection, please contact Mr V Buddan (telephone 031 311 9055) of my Central Planning Section. The first inspection will be carried out by TE at no cost to you. Should subsequent visits be required to inspect the accommodation as a result of the accommodation not complying with TE's requirements on the first inspection, a fee of R 1123,00 (inclusive of VAT) will be charged for each inspection visit thereafter.

After the commissioning of the substation, 24-hour unimpeded access is required to the substation.

Yours faithfully

VEER N RAMNARAIN

DEPUTY HEAD: MV/LV OPERATIONS