


PLAN ON CROSS ARM ANGLES



ATTACHMENT HEIGHT DETAIL

POLE LENGTH L F (m)	POLE LENGTH L G (m)	C A H (m)				P.D. (m)
		B	M	T	E/W	
20.8	18.2	10.83	12.7	14.58	18.2	2.6
21.9	19.2	11.83	13.7	15.58	19.2	2.7
22.9	20.1	12.73	14.6	16.48	20.1	2.8
24.1	21.2	13.83	15.7	17.58	21.2	2.9
25.6	22.7	15.33	17.2	19.08	22.7	2.9
27.2	24.2	16.83	18.7	20.58	24.2	3.0

THIS DRAWING IS RELEVANT FOR
GUYED AND FREE STANDING STRUCTURES

0	AB	15.03 2002	FIRST ISSUE/EERSTE UITREIKING	SLR	RAB		
REV	AUTH MAG	DATE DATUM	REVISION/REVISIES	BY DEUR	CHKD NAGES	D-DT	REFERENCE DRAWINGS
			INDEX REF/INDEXSVRW				
DRG.TEK REGISTR							
CHKD NAGES	RAB	16.03 2002					
DRAWN GETEKEN	SLR	15.03 2002	APPROVED AB	CAD.REF:			REV
SCALE SKAAL	NTS		26/04/2002	FILE No.:			0

DISTRIBUTION TECHNOLOGY
132KV SUSPENSION X-ARM
GENERAL ARRANGEMENT FOR
SINGLE STEEL POLE STRUCTURE